

Manual of Petroleum Management Standard Chapter 2—Tank Calibration

Section 2A—Measurement and Calibration of Upright Cylindrical Tanks by the Manual Tank Strapping Method

FIRST EDITION, FEBRUARY 1995



American Petroleum Institute
1220 L Street, Northwest
Washington, D.C. 20005



STEP

One of the most significant long-term trends affecting the future vitality of the petroleum industry is the public's concerns about the environment. Recognizing this trend, API member companies have developed a positive, forward looking strategy called STEP: Strategies for Today's Environmental Partnership. This program aims to address public concerns by improving industry's environmental, health and safety performance; documenting performance improvements; and communicating them to the public. The foundation of STEP is the API Environmental Mission and Guiding Environmental Principles. API standards, by promoting the use of sound engineering and operational practices, are an important means of implementing API's STEP program.

API ENVIRONMENTAL MISSION AND GUIDING ENVIRONMENTAL PRINCIPLES

The members of the American Petroleum Institute are dedicated to continuous efforts to improve the compatibility of our operations with the environment while economically developing energy resources and supplying high quality products and services to consumers. The members recognize the importance of efficiently meeting society's needs and our responsibility to work with the public, the government, and others to develop and to use natural resources in an environmentally sound manner while protecting the health and safety of our employees and the public. To meet these responsibilities, API members pledge to manage our businesses according to these principles:

- To recognize and to respond to community concerns about our raw materials, products and operations.
- To operate our plants and facilities, and to handle our raw materials and products in a manner that protects the environment, and the safety and health of our employees and the public.
- To make safety, health and environmental considerations a priority in our planning, and our development of new products and processes.
- To advise promptly appropriate officials, employees, customers and the public of information on significant industry-related safety, health and environmental hazards, and to recommend protective measures.
- To counsel customers, transporters and others in the safe use, transportation and disposal of our raw materials, products and waste materials.
- To economically develop and produce natural resources and to conserve those resources by using energy efficiently.
- To extend knowledge by conducting or supporting research on the safety, health and environmental effects of our raw materials, products, processes and waste materials.
- To commit to reduce overall emissions and waste generation.
- To work with others to resolve problems created by handling and disposal of hazardous substances from our operations.
- To participate with government and others in creating responsible laws, regulations and standards to safeguard the community, workplace and environment.
- To promote these principles and practices by sharing experiences and offering assistance to others who produce, handle, use, transport or dispose of similar raw materials, petroleum products and wastes.

Manual of Petroleum Management Standard Chapter 2—Tank Calibration

Section 2A—Measurement and Calibration of Upright Cylindrical Tanks by the Manual Tank Strapping Method

Measurement Coordination

FIRST EDITION, FEBRUARY 1995

**American
Petroleum
Institute**



SPECIAL NOTES

1. API PUBLICATIONS NECESSARILY ADDRESS PROBLEMS OF A GENERAL NATURE. WITH RESPECT TO PARTICULAR CIRCUMSTANCES, LOCAL, STATE, AND FEDERAL LAWS AND REGULATIONS SHOULD BE REVIEWED.
2. API IS NOT UNDERTAKING TO MEET THE DUTIES OF EMPLOYERS, MANUFACTURERS, OR SUPPLIERS TO WARN OR PROPERLY TRAIN AND EQUIP THEIR EMPLOYEES, AND OTHERS EXPOSED, CONCERNING HEALTH AND SAFETY RISKS AND PRECAUTIONS, NOR UNDERTAKING THEIR OBLIGATIONS UNDER LOCAL, STATE, OR FEDERAL LAWS.
3. INFORMATION CONCERNING SAFETY AND HEALTH RISKS AND PROPER PRECAUTIONS WITH RESPECT TO PARTICULAR MATERIALS AND CONDITIONS SHOULD BE OBTAINED FROM THE EMPLOYER, THE MANUFACTURER OR SUPPLIER OF THAT MATERIAL, OR THE MATERIAL SAFETY DATA SHEET.
4. NOTHING CONTAINED IN ANY API PUBLICATION IS TO BE CONSTRUED AS GRANTING ANY RIGHT, BY IMPLICATION OR OTHERWISE, FOR THE MANUFACTURE, SALE, OR USE OF ANY METHOD, APPARATUS, OR PRODUCT COVERED BY LETTERS PATENT. NEITHER SHOULD ANYTHING CONTAINED IN THE PUBLICATION BE CONSTRUED AS INSURING ANYONE AGAINST LIABILITY FOR INFRINGEMENT OF LETTERS PATENT.
5. GENERALLY, API STANDARDS ARE REVIEWED AND REVISED, REAFFIRMED, OR WITHDRAWN AT LEAST EVERY FIVE YEARS. SOMETIMES A ONE-TIME EXTENSION OF UP TO TWO YEARS WILL BE ADDED TO THIS REVIEW CYCLE. THIS PUBLICATION WILL NO LONGER BE IN EFFECT FIVE YEARS AFTER ITS PUBLICATION DATE AS AN OPERATIVE API STANDARD, OR WHERE AN EXTENSION HAS BEEN GRANTED, UPON REPUBLICATION. STATUS OF THE PUBLICATION CAN BE ASCERTAINED FROM THE API AUTHORIZING DEPARTMENT [TELEPHONE (202) 682-8000]. A CATALOG OF API PUBLICATIONS AND MATERIALS IS PUBLISHED ANNUALLY AND UPDATED QUARTERLY BY API, 1220 L STREET, N.W., WASHINGTON, DC 20005.

FOREWORD

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to Measurement Coordination, Exploration and Production Department, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005.

CONTENTS

SECTION 2A—MEASUREMENT AND CALIBRATION OF UPRIGHT CYLINDRICAL TANKS BY THE MANUAL TANK STRAPPING METHOD

	Page
2.2A.1 Scope.....	1
2.2A.2 Referenced Publications	1
2.2A.3 Safety	1
2.2A.4 Definitions	2
2.2A.5 Significance	2
2.2A.6 Equipment.....	2
2.2A.6.1 Tapes for Height Measurement.....	2
2.2A.6.2 Tapes for Circumference Measurement.....	3
2.2A.6.3 Accessory Equipment.....	3
2.2A.7 Calibration of Working Tape with the Master Tape.....	4
2.2A.8 General Practices	5
2.2A.9 Tank Status Before Calibration.....	5
2.2A.10 Descriptive Data	5
2.2A.11 Tolerances	5
2.2A.12 Shell Plate Thicknesses.....	5
2.2A.13 Vertical Tank Measurements.....	10
2.2A.14 Circumferential Measurements.....	12
2.2A.14.1 Preparation.....	12
2.2A.14.2 Physical Measurements	13
2.2A.15 Deadwood Measurement	15
2.2A.16 Tank Bottoms	18
2.2A.17 Floating Roofs	18
2.2A.17.1 General	18
2.2A.17.2 Floating Roof Weight	18
2.2A.17.3 Deadwood Determination.....	18
2.2A.17.4 Deducting Floating Roof Displacement	18
2.2A.18 Insulated Tanks	18
2.2A.19 Tank Capacity Table Development: Calculation Procedures.....	21
2.2A.19.1 Capacity Table Requirements.....	22
2.2A.19.2 Calibration of the Master Tape to 60°F	22
2.2A.19.3 Conversion of Outside to Inside Circumferences.....	22
2.2A.19.4 Deductions for Circumference Tape Rises.....	22
2.2A.19.5 Expansion and Contraction of Steel Tank Shells Due to Liquid Head.....	25
2.2A.19.6 Expansion and Contraction of Steel Tank Shells Due to Temperature.....	27
2.2A.19.7 Effect of Tilt on Cylindrical Portion of Tank.	27
2.2A.19.8 Floating Roofs	28
2.2A.19.8.1 Liquid Calibration for Floating Roof Displacement	28
2.2A.19.8.2 Measurement Procedure for Floating Roof Displacement.....	28
2.2A.19.8.3 Liquid Level Above Position B	28
2.2A.19.8.4 Capacity Table With Floating Roof Treated as Deadwood	29
2.2A.19.8.5 Capacity Table of Gross or Open-Tank Capacity.....	29
2.2A.19.9 Summary Data on the Capacity Table	30
2.2A.19.10 Recalibration Requirements	30
2.2A.19.11 Certification of Capacity Tables	30

APPENDIX A—GUIDELINES FOR RECALIBRATION OF STORAGE TANKS.....	31
--	----

	Page
APPENDIX B— EXAMPLE CALCULATIONS FOR UPRIGHT CYLINDRICAL STEEL TANK—ABOVEGROUND	35
APPENDIX C— GUIDELINES FOR COMPUTER INPUT	47
APPENDIX D— SHELL TEMPERATURE CORRECTION FACTORS	49
APPENDIX E— UNDERGROUND TANKS	53
APPENDIX F— TANK CALIBRATION METHOD SELECTION	57

Figures

1—Height Measuring Tape and Bob	2
2—Strapping Tapes for Circumference Measurements	3
3—Jointed Type Tape Guides	4
4—Record Form for Deadwood	6
5—Measurement Locations for Welded Upright Tanks	9
6—Measurement Locations for Riveted Shingled Arrangement	10
7—Measurement Locations for Bolted Tanks	11
8—Vertical Tank Measurements-Welded	12
9—Vertical Tank Measurements-Bolted	14
10—Vertical Tank Measurements-Riveted	15
11—Effective Inside Tank Height-Cone Roof	16
12—Effective Inside Tank Height-Floating Roof	17
13—Spherical Segment (Dished), Hemispherical and Semi-Ellipsoidal Bottoms, Convex and Accessible Measurements of Upright Tanks	19
14—Coned Downward Bottom and Accessible Measurements of Upright Tanks	20
15—Diagram of Floating Roof at Rest (A) and Floating (B)	21
16—Typical Steel Pontoon Floating Roof With Single Center Deck	25
17—True Circumference Versus Tape Path at Axial Lap Joint Away From Circumferential Joint	26
B-1—Upright Cylindrical Tanks Composite Construction	35
B-2—Typical NIST Report of Calibration	36
E-1—Locations of Measurements on Upright Cylindrical Concrete Underground Tanks	54
E-2—Locations of Measurements on Rectangular Steel or Concrete Underground Tanks	55
F-1—External Floating-Roof Tank Decision Chart	58
F-2—Fixed-Roof Tank Decision Chart	58
F-3—Chart for Internal Floating-Roof Tanks	58

Tables

1—Suggested Record Form “A” for Measurements of Upright Cylindrical Tanks	7
2—Suggested Record Form “B” for Measurements of Upright Cylindrical Tanks	8
3—Elevations for Circumference Measurements on Various Types of Upright Cylindrical Tanks	13
4—Circumferential Tolerances	13
5—Customary Version Capacity Table	23
6—SI Version Capacity Table	24
A-1—Tank Bottom Course Inside Diameter Variations	31
A-2—Tank Bottom Course Plate Thickness	31
A-3—Volume Correction for Table Tilt	31
A-4—Tank Shell Temperature Variations	31
A-5—Product Specific Gravity Variations	32

	Page
B-1—Typical Measurement Record of an Upright Cylindrical Steel Tank for Example Calculations	37
B-2—Typical NIST Report of Calibration	38
B-3A—Tank Table Run Sheet	44
B-3B—Run Sheet for Soft Conversion to Metric	45

Chapter 2—Tank Calibration

SECTION 2A—MEASUREMENT AND CALIBRATION OF UPRIGHT CYLINDRICAL TANKS BY THE MANUAL TANK STRAPPING METHOD

2.2A.1 Scope

2.2A.1.1 This standard describes the procedures for calibrating upright cylindrical tanks used primarily for the storage of petroleum liquids. Section 2A first addresses procedures for making necessary measurements to determine total and incremental tank volumes and then presents the recommended procedures for computing volumes.

2.2A.1.2 Both SI (metric) and customary units are presented where appropriate in the chapter. SI and customary conversions may not necessarily be exact. The SI units often reflect what is available in commercial equipment.

2.2A.1.3 The standard also provides guidelines for recalibration and for computerization of capacity tables.

2.2A.2 References

2.2A.2.1 REFERENCED PUBLICATIONS

The following publications are cited in this standard:

API

Std 650 *Welded Steel Tanks for Oil Storage*

Std 653 *Tank Inspection, Repair, Alteration, and Reconstruction*

Std 2555 *Liquid Calibration of Tanks*

Manual of Petroleum Measurement Standards

Chapter 2, "Tank Calibration," Section 2B,
"Calibration of Upright Cylindrical Tanks
Using the Optical Reference Line Method"

ICS¹/OCIMF²/IAPH³

*International Safety Guide for Oil Tankers and Terminals (ISGOTT)*⁴

IP⁵

Petroleum Measurement Manual

Part 2, "Tank Calibration," Section 1, "Vertical Cylindrical Tanks, Measurement Methods"

NFPA⁶

306 *Control of Gas Hazards on Vessels*

¹International Chamber of Shipping, 30/32 Mary Axe Street, London EC3A 8ET, England.

²Oil Companies International Marine Forum, Portland House, 6th Floor, Stag Place, London SW1E 5BH, England.

³International Association of Ports and Harbors, Kotohira-Kaikan Building, 2-8, Toranomon 1-Chome Minato-Ku, Tokyo 105, Japan.

⁴ISGOTT is available from Witherby & Co., Ltd. (Marine Publishing), 32/36 Aylesbury Street, London EC1R 0ET, England.

⁵IP, 61 New Cavendish Street, London W1M 8AR, England.

⁶National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, Massachusetts 02269-9101.

2.2A.2.2 INFORMATIVE PUBLICATIONS

The following publications are listed for information only:

API

Std 2551 *Measurement and Calibration of Horizontal Tanks*

Std 2552 *Measurement and Calibration of Spheres and Spheroids*

Std 2554 *Measurement and Calibration of Tank Cars*
Manual of Petroleum Measurement Standards

Chapter 2, "Tank Calibration," Section 7,
"Calibration of Barge Tanks," Section 8A,
"Calibration of Tanks on Ships and Ocean-
going Barges"

ISO⁷

7507-1 *Petroleum and Liquid Petroleum Products: Volumetric Calibration of Vertical Cylindrical Tanks, Part 1, "Strapping Method"*

7507-2 *Petroleum and Liquid Petroleum Products: Volumetric Calibration of Vertical Cylindrical Tanks, Part 2, "Optical Reference Line Method"*

7507-3 *Petroleum and Liquid Petroleum Products: Volumetric Calibration of Vertical Cylindrical Tanks, Part 3, "Optical Triangulation Method"*

2.2A.3 Safety

2.2A.3.1 Before entering any tank, permission must be obtained from the Terminal Supervisor, authorized official, or other responsible person in charge. This responsible person should supply information regarding particular materials and conditions or the applicable Material Safety Data Sheet (MSDS).

2.2A.3.2 Due consideration should be given to applicable safety procedures. Safety considerations include, but are not limited to, potential electrostatic hazards, potential personnel exposure (and associated protective clothing and equipment requirements), and potential explosive and toxic hazards associated with a storage tank's atmosphere. The physical characteristics of the product and existing operational conditions should be evaluated, and applicable international, federal, state, and local regulations should be observed.

⁷International Organization for Standardization. ISO publications are available from ANSI.

2.2A.3.3 In addition, before entering a storage tank, safety procedures designated by the employer, the terminal operator, and all other concerned parties should also be observed. It shall be indicated that the tank is “Safe for Workers” and/or “Safe for Hot Work,” as prescribed in NFPA 306, U.S. Coast Guard, OSHA, or other international, federal, state, or local regulations that may apply. Such testing must be made at least every 24 hours or more frequently when conditions warrant.

2.2A.3.4 Internationally, the *International Safety Guide for Oil Tankers And Terminals* (ISGOTT) should be consulted.

2.2A.3.5 Furthermore, another person should stand watch at the tank entrance for the duration, and sound an alarm if an emergency occurs. Appropriate protective clothing and equipment should be used. Normal safety precautions with respect to staging and ladders must also be observed.

2.2A.4 Definitions

2.2A.4.1 A *Capacity Table* or a *Tank Capacity Table* shows the capacities of, or volumes in a tank for various liquid levels measured from the reference gauge point.

2.2A.4.2 *Deadwood* refers to any object within the tank, including a floating roof, which displaces liquid and reduces the capacity of the tank; also any permanent appurtenances on the outside of the tank, such as cleanout boxes or manholes, which increase the capacity of the tank.

2.2A.4.3 *False Bottom* is commonly referring to a new bottom installed on top of the previous tank bottom, which will reduce the bottom ring height and the effective inside tank height.

2.2A.4.4 *Master Tape* is a tape that is used for calibrating working tapes for tank measurement and is identified with a Report of Calibration at 68 degrees Fahrenheit (68°F) [20 degrees Celsius (20°C)] and at a specific tension designated by the National Institute of Standards and Technology (NIST) or an equivalent international standard organization.

2.2A.4.5 *Tank Strapping* is the term commonly applied to the procedure for measuring tanks to provide the dimensions necessary for computing capacity tables that will reflect the quantity of product in a tank at any given depth/level.

2.2A.4.6 *Reference Gauge Height* is the vertical distance between the reference point on the gauge hatch and the striking point on the tank floor or on the gauge datum plate.

2.2A.4.7 *Successive Tangent Method* is the measurement of a circumference on a tank when the tape is not long enough to span the entire circumference of a tank.

2.2A.4.8 *Continuous Wraparound Procedure* is the measurement of a tank circumference with a tape that is long enough to span the entire circumference of a tank.

2.2A.5 Significance

2.2A.5.1 Accurate tank circumference measurements are critical in determinations of liquid volume and the development of capacity table for Custody Transfer transactions and inventory control. This standard provides measurement and computational procedures for the development of such a capacity table.

2.2A.5.2 All such measurements should be witnessed by all parties involved to ensure compliance with the procedure outlined in the standard and overall measurement integrity.

2.2A.6 Equipment

The equipment used in dimensional Tank Calibration is described in 2.2A.6.1 through 2.2A.6.3. All equipment shall be in good working condition. All tapes shall be in one piece and free of kinks.

2.2A.6.1 TAPES FOR HEIGHT MEASUREMENT

For height measurements, a steel tape (see Figure 1), of convenient length, $\frac{3}{8}$ or $\frac{1}{2}$ inches wide and 0.008 to 0.012 inches thick, graduated in feet and inches to eighths of an inch, or in feet, tenths, and hundredths of a foot is recommended. (For metric tapes, refer to *IP Petroleum Measurement Manual*, Part 2, Section 1) Graduations shall be




Figure 1—Height Measuring Tape and Bob

accurate within $\frac{1}{16}$ inch or 0.005 foot (or to nearest millimeter) throughout that portion of the tape to be used.

2.2A.6.2 TAPES FOR CIRCUMFERENCE MEASUREMENT

For circumference measurements, a mild steel tape, (see Figure 2) of convenient length relative to the tank circumference is recommended. The working tape is usually 100, 200, 300, or 500 feet long and should not be more than $\frac{1}{4}$ inch wide, and approximately 0.01 inch thick. The tape may be graduated in feet, with an extra 1 foot length at the zero end of the tape and graduated in tenths and hundredths of a foot, or it may be graduated in feet, tenths and hundredths of a foot throughout its length (for metric tapes, refer to IP *Petroleum Measurement Manual*, Part 2, Section 1). All working tapes should be calibrated with a Master tape (refer to 2.2A.7).

2.2A.6.3 ACCESSORY EQUIPMENT

Additional measuring equipment recommended is listed below. Other similar equipment may be used, provided it will give the same results.

- a. Reels and tapes shall be equipped with appropriate reels and handles.
- b. Tape clamps: for assurance of positive grip on tape, clamps shall be used.
- c. A spring tension scale is needed.
- d. Rope and ring: two lengths of rope line fitted with snap and ring are to be used in raising and lowering circumference measurement tape. Alternatively, jointed-type pole guides may be used (see Figure 3).
- e. Transit or level or both are used when required.
- f. Ladders to facilitate handling of tapes and removal of scale, rust, dirt, etc. from the path of measurement are needed.
- g. An ultrasonic thickness measurement device is used.
- h. A plumb line is needed.
- i. Depth Gauge: a depth gage of case-hardened steel, 6 inches in length, graduated to $\frac{1}{4}$ inch (1 millimeter resolution and read to nearest 0.5 millimeter) is for determination of thickness of steel plates is needed.
- j. Straightedge: a straightedge of appropriate length and a profile board for measuring knuckles are used.
- k. Calipers and special clamps for spanning obstructions in making circumference measurements, the following are recommended:




Figure 2—Strapping Tapes for Circumference Measurements




Figure 3—Jointed Type Tape Guides

1. Maximum expansion calipers of 6 inches (or 15 centimeters) for spanning the smaller obstructions, such as vertical flanges, bolt heads, etc.
2. Maximum expansion calipers of 18 inches (45 centimeters) or 24 inches (61 centimeters) for spanning the larger obstructions, such as butt straps, etc.
3. Special clamps may be substituted for calipers in measuring projecting flanges.

The following may be useful equipment: a six foot ruler for general measurements, shovel, spirit level, awl and scribe, marking crayon, record paper, and cleaning instruments, such as a putty knife and a hard bristle brush for eliminating dirt, grease, paint scale, rust particles, etc. from the path of circumference measurements.

2.2A.7 Calibration of Working Tape with the Master Tape

2.2A.7.1 The tape used for circumference measurements shall be calibrated (for required tension) by matching it against the master tape in the following manner:

- a. Choose a convenient tape path (i.e. 20 percent of ring height) on the lower ring, and place the master tape around the tank.
- b. Using the successive tangent method, make a scribe mark on the shell, determining the origin of the circumference. Apply the tape, with constant application of tension at which the master tape was certified to be accurate, to the tank shell at the proper tape path with the tape's zero mark located exactly on the scribe mark designating the origin point. The tape is placed in position with required tension, and the last reading on the tape is scribed on the tank shell at each 100 feet (or 30 meters) or fraction thereof. This measurement is

written on the tank shell and recorded. This procedure is repeated until the entire circumference is measured.

- c. Total the measurements obtained.
- d. Place the working tape around the tank, using the same tape path, by the continuous "wraparound" procedure.
- e. Slide the working tape to break frictional resistance, and apply tension sufficient to equal the measurement obtained with the master tape.
- f. The amount of tension, in pounds, required to be pulled on the working tape to obtain the same measurement as that recorded with the master tape shall be applied to the working tape when taking circumferential measurements. If the tension determined to be proper for the working tape is insufficient to hold the tape in the proper position, additional tension should be applied and a correction made to bring the reading into agreement with that obtained with the master tape.

2.2A.7.2 The preceding procedure shall be carried out when calibrating other tanks whose circumference differs by more than 20 percent from the calibrated tape section and where tank surfaces are different.

2.2A.7.3 Two working tape corrections are illustrated in the following examples. Note that conditions one and two for application of working tape corrections apply for either case, that is, where the master tape and working tape are of equal or different lengths. The same procedure applies for metric measurements.

a. Condition No. 1: If additional tension is required to be applied to the working tape to equal the measurement obtained by the master tape, then no mathematical correction is needed. The additional tension required to equal the master tape measurement must be applied to all subsequent circumferences obtained with the working tape.

b. Condition No. 2: If the same or additional tension is applied to both the master tape and the working tape and the measurements do not agree, then a mathematical correction shall be applied as indicated in the examples below. The determined differences must be applied to all working tape circumferences before the processing of the capacity table.

c. Examples

Example 1:

314.515 feet

Master tape at 10 pounds tension per 100 feet or part thereof.

314.475 feet

Working tape at 20 pounds tension.

0.040 feet

Correction for working tape to be *added* to each circumference measured.

Example 2:

314.515 feet

Master tape at 10 pounds tension per 100 feet or part thereof.

314.590 feet

Working tape at 20 pounds tension.

0.075 feet

Correction for working tape to be *subtracted* from each circumference measured.

2.2A.8 General Practices

All measurements and descriptive data taken at the tank site should be checked and immediately, legibly recorded with the recording preferably assigned to a single individual, as follows:

- a. All measurements should be taken without disruption and preferably on the same day of calibration with the liquid level remaining static. If measurements have to be disrupted, interrupted tank measurement work may be continued at a later date, without repeating the work previously completed, provided all records of the work are complete and legible. Movement of liquid into or out of the tank may be tolerated, provided a clearly marked liquid gauge and average temperatures of both liquid and outside atmosphere are included as parts of these subsequent strapping operations.
- b. All data and procedures necessary for the preparation of capacity tables should be supported by sound engineering principles.
- c. Each tank shall be identified clearly and legibly by number or by some other suitable marking, but this identification should not be painted on tank attachments.

2.2A.9 Tank Status Before Calibration

2.2A.9.1 Before calibration, the tank shall have been filled at least once at its present location with liquid at least as dense as is expected to contain. The hydrostatic test (for a period of approximately 24 hours) will usually satisfy this requirement. Any hydrostatic test should be performed in accordance with applicable construction and operating standards (API Standard 650 and 653). When possible, the liquid in the tank should be allowed to stand still for approximately 24 hours before calibration is performed.

2.2A.9.2 Tanks with a nominal capacity of 500 barrels or less may be strapped at any condition of fill, provided the tanks have been filled at least once at their present location. Small movements of oil into or out of such tanks are allowed during strapping.

2.2A.9.3 Tanks with a nominal capacity of more than 500 barrels should be handled this way:

- a. Bolted Tanks (usually in Production Service) must have been filled at least once at their present location and must be at least two-thirds full when strapped. Small movements of oil into or out of such tanks are allowed during strapping.
- b. Riveted Tanks and/or Welded Tanks must have been filled at least once at their present location. They may be strapped at any condition of fill and the full capacity computed as shown in 2.2A.19.5. No movement of oil into or out of such tanks is allowed during the strapping operation.

2.2A.10 Descriptive Data

2.2A.10.1 Complete descriptive data should be entered on the Tank Measurements Record Form being used. Suggested record forms are shown in Figure 4 and Tables 1 and 2.

2.2A.10.2 The API gravity and the temperature of the tank's contents at the time of strapping shall be obtained and recorded. The average API gravity, average overall ambient temperature at which the tank shall operate and maximum safe fill height (refer to 2.2A.13.5) shall be obtained from the tank owner and recorded.

2.2A.10.3 Supplemental sketches or notations, each completely identified, dated, and signed, should accompany the strapping report. These should indicate the following:

- a. Typical horizontal and vertical joints.
- b. Number of plates per ring.
- c. Location of rings at which thickness of plates change arrangement.
- d. Size of angles at top and bottom of shell.
- e. Location and size of pipes and manways.
- f. Dents and bulges in shell plates.
- g. Amount of lean from vertical in relation to the reference gauge point.
- h. Procedure used in bypassing a large obstruction, such as a cleanout box or insulation box located in the path of a circumferential measurement.
- i. Location of tape path different from that shown in Figures 5 through 7.
- j. Location and elevation of a possible datum plate.
- k. All other items of interest and value which will be encountered.

2.2A.10.4 Entries of data on a tank measurements record form or supplemental data sheets should not be erased. If alteration is necessary, the entry to be changed should be marked out with a single line and the new data recorded adjacent to the old entry.

2.2A.11 Tolerances

2.2A.11.1 Single circumferential measurements should be read and recorded to the nearest 0.005 feet (or nearest millimeter), which is equal to one-half of the distance between two adjacent hundredth-foot division marks on the tape. Therefore, all circumferential measurements should be recorded through the third decimal place.

2.2A.11.2 Vertical tank measurements should be read and recorded to the nearest $\frac{1}{16}$ inch (or nearest 1 millimeter).

2.2A.11.3 Thermometers should be read to the nearest 1°F (or 0.5°C).

2.2A.11.4 Tank plate thicknesses should be determined to the nearest $\frac{1}{16}$ inch (1 millimeter resolution and read to nearest 0.5 millimeter).

2.2A.11.5 Deadwood should be determined and located by measurement readings to the nearest $\frac{1}{8}$ inch (or 3 millimeter).

2.2A.12 Shell Plate Thickness

2.2A.12.1 Plate thickness should be measured by Ultra-

Table 1—Suggested Record Form "A" for Measurements of Upright Cylindrical Tanks

Report No.:

Date:

Tank No.:

(Old Tank No.):

Owner's Name:

Plant or Property Name:

Location:

Manufactured by:

Erected by:

Prepare:Copies: Increments in: Fractions to:

Table Form or Size Desired:

Height: Shell: Gauging:

Type of Roof: Weight of Floating Roof:

Tank Contents—Name: Avg. Liquid Temp., °F:

Gauge: ft. in.; Innage to: Shell Floor or Outage

Hydrometer Reading: at °F Sample Temperature

Gauging Reference Point to Top of Top Angle: ft. in.; Normal Service:

Shell Circumferences:

A.	D.	G.
B.	E.	H.
C.	F.	J.

Descriptions of Shell Plates and Joints ^a

	Ring No.	Thickness	Type of Vertical Joint	Set, in or out	Width of Lap or Strap	Thickness of Lap or Strap	No. of Joints	Inside Ring Height
	7							
	6							
	5							
	4							
	3							
	2							
(Btm. Ring)	1							

Shell Connections: ^b

No.	Description	Elevation—Top of Floor to Bottom of Connection
1		
2		
3		
4		
5		
6		

Amount of Tank Lean from Vertical: ^c in. ft. in.

Circumference Tape Used: Date Chk'd at

Tank Measured by: for

Deadwood and Tank Bottom—Use separate sheets. For each piece or item of deadwood record description, size, number of occurrences, and location related to other height measurement data recorded.

Explanatory Notes (such as type of bottom, height or depth of crown, etc.)

.....

Note: No. = Number; Avg. Liquid Temp. = Average Liquid Temperature; ft. = foot/feet; in. = inch(es)

^aShow sketches of vertical and horizontal joints on back of this Table.^bShow circumferential location on plan view sketched on back of this Table.^cShow direction of lean on plan view sketched on back of this Table.

Table 2—Suggested Record Form "B" for Measurements of Upright Cylindrical Tanks

Report No.:
 Date:
 Tank No.:
 (Old Tank No.):
 Owner's Name:
 Plant or Property Name:
 Location:
 Manufactured by:
 Erected by:
 Prepare: Copies: Increments in : Fractions to:
 Table Form or Size Desired:
 Height: Shell : Gauging:
 Type of Roof: Weight of Floating Roof:
 Tank Contents—Name: Avg. Liquid Temp., °F:
 Gauge: ft. in.; Tank Service: API Gravity:
 Hydrometer Reading: at °F Sample Temperature

Shell Circumferences:

A. D. G.
 B. E. H.
 C. F. J.

Descriptions of Shell Plates and Joints:

	Ring No.	Thickness	Type of Vertical Joint	Set, in or out	Width of Lap or Strap	Thickness of Lap or Strap	No. of Joints	Inside Ring Height
	7							
	6							
	5							
	4							
	3							
	2							
(Btm. Ring)	1							

Deadwood and Remarks (use reverse side if necessary):

<u>Deadwood</u>		<u>Elevation</u>	
<u>Description</u>	<u>No.</u>	<u>Size</u>	<u>From</u> <u>To</u>
.....			
.....			
.....			
.....			

Type of Bottom: Height of Crown:
 Witness: Measurements by:

Note: Avg. Liquid Temp.=Average Liquid Temperature; °F=degrees Fahrenheit.; in.=inches; ft=foot; Btm = Bottom

sonic measurement device as the preferred method. A minimum of two measurements per ring should be obtained.

2.2A.12.2 Plate thickness measurements obtained before or during construction and recorded on a properly identified strapping record may be accepted. In the absence of any direct measurements of plate thickness obtained and recorded before or during construction, the least preferred

method is to use the plate thickness shown on the fabricator's drawings and so identified in the calculation records or information provided by tank owner.

2.2A.12.3 The alternate method of measuring plate thickness is by depth gauge. Where the type of construction leaves the plate edges exposed, a minimum of two thickness measurements should be made on each ring. The arith-




Figure 5—Measurement Locations for Welded Upright Tanks

metrical average of the measurements for each ring should be recorded; all thickness measurements, properly identified, should be noted on a supplemental data sheet which should form a part of the measurement record. Care should be taken to avoid plate thickness measurements at locations where edges have been distorted by caulking.

2.2A.13 Vertical Tank Measurements

2.2A.13.1 Shell height is the vertical distance between bottom of bottom angle (or top of floor plate) and top of top angle, and should be measured at a point near the reference gauge hatch (see Figures 8, 9, and 10).

2.2A.13.1.1 Additional measurements should be made, as required, at other identified points sufficient to investigate and describe known or suspected conditions in the tank, such as tilt or false bottom. Locations of measurements should be marked on a supplemental sketch.

2.2A.13.1.2 The amount of tilt in shell height should be measured and recorded. The measurements for possible tilt may be made in conjunction with measurements of shell heights using a theodolite, an optical plummet, or a plumb bob.

2.2A.13.2 A description of the reference gauge point should be included in the record, for example: to top lip of 8-inch (or 20 centimeter) diameter hatch, opposite hinge.

2.2A.13.3 A comparison should be made immediately of the reference gauge height with the sum of the shell height plus the height from the top of the top angle of the tank shell to the level of the reference gauge point on the hatch rim, in order to investigate the possible existence of a datum plate or false bottom.

2.2A.13.3.1 The result of this field investigation should be recorded by identifying the reference gauge height as a distance to the floor or to the datum plate. The measurements and calculations involved should be attached to, and become a part of, the measurement record.

2.2A.13.3.2 If a false bottom is known or suspected to be present, the record should be so marked.

2.2A.13.4 Effective inside tank height is a vertical distance along the gauging path (see Figures 11 and 12). This is of primary concern to the capacity table calculations, establishing the upper and lower limits of variable gauges to be provided for in the capacity table.

2.2A.13.4.1 The maximum upper limit of the capacity table can be one of the following two items:

- Effective inside tank height.
- Maximum fill height requested by the tank owner, such as at the underside of an overflow.

2.2A.13.4.2 If the effective inside tank height should be obtained directly on the tank, this height should be measured and reported as such. If effective inside tank height cannot be measured directly, the person responsible for obtaining the

measurements should obtain as-built blueprints to enable calculation of the effective inside tank height.

2.2A.13.5 In some installations, an overflow line or other appurtenance is connected to the tank shell just below the top angle and provides a potential liquid overflow level at some point below the top of the shell (see Figure 12).




Figure 6—Measurement Locations for Riveted Shingled Arrangement

2.2A.13.5.1 The measurement record should include a complete description of such a connection, including size and location and whether or not a valve which can be closed and sealed is included in the line. If such a valve is present, its location should be included in the record.

2.2A.13.5.2 If the connection cannot be closed and sealed against overflow, then the effective inside tank height is the

vertical distance from the striking point on the tank floor, or datum plate, upward to the level at which the tank's contents will begin to overflow; the tank capacity between the point of overflow and the tank roof should be disregarded in the capacity table.

2.2A.13.5.3 If the connection can be closed and sealed against overflow, then the effective inside tank height and the




Figure 7—Measurement Locations for Bolted Tanks

capacity table, should extend upward to the top of the top angle.

2.2A.13.5.4 In this latter case, in which the capacity table is extended upward beyond the connection, the capacity table should include a note at the elevation of the connection citing its presence and stipulating the condition under which that portion of the capacity table may be used.

2.2A.13.5.5 The safe fill height, when required to be indicated in the capacity table must be so specified by the owner. The safe fill height in most instances will be less than maximum fill height.

2.2A.13.5.6 Each ring height shall be measured and recorded (see Figure 5).

2.2A.13.5.7 Where rings are lapped horizontally, the lap shall be reported so that the inside height of the ring can be developed by calculations.

2.2A.14 Circumferential Measurements

2.2A.14.1 PREPARATION

2.2A.14.1.1 The calibration technician responsible for measuring the tank should first determine where circumferential measurements are to be taken. Circumferential measurements are to be taken on the tank shell. No circumferential measurements are to be taken over insulation. A summary of elevations for circumference measurements on various types of upright cylindrical tanks is shown in Table 3.




Figure 8—Vertical Tank Measurements – Welded

Table 3—Elevations for Circumference Measurements on Various Types of Upright Cylindrical Tanks

Type of Tank Construction	Circumference Measurement Elevations
Welded Steel, One or More Rings	20 percent down from top of each ring whether Butt or Lap Joints ^a
Riveted Steel, Shingled Arrangement	Lowest point on each ring and 1 foot (or 300 millimeters) below top of top ring ^b
Riveted Steel, In-and-Out Arrangement	Lowest point above horizontal rivet rows on each ring, and 1 foot (or 300 millimeters) below top of top ring ^b
Riveted Steel, Combination Shingled and In-and-Out Arrangement	Lowest point above horizontal rivet rows on each ring, and 1 foot (or 300 millimeters) below top of top ring ^b
Steel Tank One Ring High, Riveted Lap Joints on bottom of shell	25 and 75 percent above
Bolted Steel, Lapped Vertical Joints	25 and 75 percent above bottom of each ring
Bolted Steel, Flanged Vertical Joints	75 percent above bottom of each ring

^aFor one-ring tanks, two circumferential measurements shall be taken at 20 percent and 80 percent down from top of the ring. For tanks of more than one ring, if obstructions block the tape path at the 20 percent down plane, the measurement may be taken at a point 80 percent down. If circumference measurements taken on successive rings indicate unusual variations or distortions, sufficient additional measurements should be taken to satisfy the requirements of all concerned.

^bWhen bottom angle is welded, take lowermost circumference 1 foot (or 300 millimeters) above bottom of bottom ring. Where tank shells are of composite construction, take measurements in accordance with instructions above for each type of construction.

2.2A.14.1.2 Circumferential tape paths located at elevations shown in the appropriate illustration in Figures 5 through 10 should be examined for obstructions and type of upright joints. Dirt, scale, and insulation should be removed along each path.

2.2A.14.1.3 Occasionally, some feature of construction, such as a manway or insulation box, may make it impractical to use a circumference elevation prescribed on the appropriate illustration. Then a substitute tape path located nearer to the center of the ring, may be chosen. The strapping record should include the location of the substitute path and the reason for the departure.

2.2A.14.1.4 The type and characteristics of upright joints should be determined by close examination in order to establish the procedure of measurement and equipment required. In the case of butt-strap or lap joints at which voids between tape and shell occur, the joints will be caused only by butt-strap or plate thickness, uniform at each joint; then circumferences may be measured in accordance with the procedure described in 2.2A.14.2.

2.2A.14.2 PHYSICAL MEASUREMENTS

2.2A.14.2.1 For the measurements described in 2.2A.14.1, a circumference tape of sufficient length to encircle the tank completely should be used, in which case measurement of total circumference with one reading should be taken. In the event that the tank circumference is too great to be completely encircled by the tape, alternate methods may be adopted (see Appendix F).

2.2A.14.2.2 All points at which circumferential measurements are read should be located at least 2 feet (or 600 millimeters) from an upright joint. After a circumferential measurement has been taken, the tension should be reduced sufficiently to permit the tape to be shifted. Before reading, the tape position should be verified. It should then be returned to position and required tension, and two successive readings should be taken within specified tolerances as per Table 4. The average of the two readings should be recorded as the circumferential measurement at that location.

Table 4—Circumferential Tolerances

Customary	SI
Up to 150 ft. ± 0.01 ft.	Up to 30 m ± 2 mm
150 to 300 ft. ± 0.02 ft.	30 to 50 m ± 4 mm
Over 300 ft. ± 0.03 ft.	50 to 70 m ± 6 mm
	70 to 90 m ± 8 mm
	Over 90 m ± 10 mm

Note: ft. = feet; m = meter; mm = millimeter

2.2A.14.2.3 When butt-strap or lap joints cause uniform voids between the tape and tank shell at each joint, circumference measurements should be made in accordance with 2.2A.14.2.1. The proper procedure is to measure and record the width and thickness of butt straps, and record the number of butt straps in each ring.

2.2A.14.2.4 In the case of lapped joints, one should measure and record the thickness of exposed lapped plate (see Figure 10) in each ring about the circumference, and record the number of such joints in each ring. The measured

circumferences, properly checked and recorded, should be corrected later for tape rise as described in 2.2A.19.4.

2.2A.14.2.5 When obstructions are encountered in the tape path over which it is impracticable to place the tape (for example, features which exert uneven effects on the resultant void between the tape and tank, from joint to joint) then alternate methods may be adopted (see Appendix F).

2.2A.14.2.6 For spanning obstructions in making circumference measurements, the following is recommended. To measure the span of an obstruction, apply the caliper in a horizontal position, as determined by use of a level, against the shell of the tank being strapped, near the center of a shell plate, and scribe marks on the shell with the two scribing points. Apply the circumferential working tape under required tension




Figure 9—Vertical Tank Measurements – Bolted

to the tank shell in such a position that the distance between the scribed lines along the shell surface may be estimated to the nearest 0.001 feet or to the nearest 0.5 millimeter.

2.2A.15 Deadwood Measurement

2.2A.15.1 The calibration procedures which are outlined herein are based upon internal cleanliness of the tank. The

interior upright cylindrical surface and roof-supporting members, such as columns and braces in the tank, should be clean and free from any foreign substance including, but not limited to, residue of commodities adhering to the sides, rust, dirt, emulsion, and paraffin. Examination and inspection of a tank may indicate the need for thorough cleaning if accuracy in the calibration is to be achieved.




Figure 10—Vertical Tank Measurements— Riveted

2.2A.15.2 Deadwood should be accurately accounted for, as to size and location, to the nearest $\frac{1}{8}$ inch (or 3 millimeter) in order to permit the following:

a. Adequate allowance for the volumes of liquid displaced or admitted by the various parts (see Appendix B for example calculations).

b. Adequate allocation of the effects at various elevations within the tank.

2.2A.15.3 Deadwood should be measured, if possible, within the tank. Dimensions shown on the builder's drawings or dimensions furnished by the tank owner may be accepted if actual measurement is impossible.




Figure 11—Effective Inside Tank Height – Cone Roof

2.2A.15.4 Measurements of deadwood should show the lowest and highest levels, measured from the tank bottom adjacent to the shell, at which deadwood affects the capacity of the tank (see Figure 4). Measurements should be increments which permit allowance for deadwood's varying effect on tank capacity at various elevations.

2.2A.15.5 Work sheets on which details of deadwood are sketched, dimensioned, and located should be clearly identified and should become a part of the strapping record.




Figure 12—Effective Inside Tank Height – Floating Roof

2.2A.16 Tank Bottoms

2.2A.16.1 Tank bottoms which are flat, level, and stable under varying liquid loads will have no effect on tank capacity.

2.2A.16.2 Tank bottoms conforming to geometric shapes (for example, sloping, cone down, crown up, hemispherical, semiellipsoidal, and spherical segment) have volumes which may be either computed from linear measurements or measured by liquid calibration by incremental filling, as desired.

2.2A.16.2.1 When volumes are to be computed, measurements should be made at the points shown on the applicable illustration in Figures 13–14.

2.2A.16.2.2 Any detailed differences in shape affecting the volume, not shown on the strapping report, such as knuckle radii, should be measured and recorded in sufficient detail to permit computation of the true volume.

2.2A.16.3 Where tank bottom conditions of irregular slope or shape and/or instability exist and where correct capacities cannot be determined accurately from linear measurements, liquid calibration is preferred.

2.2A.16.4 If liquid calibration is used, incremental filling of volumes are introduced into the tank, from the lowest point in the bottom to a point above which computations can be made from dimensional measurements. The procedure should be continued to a depth in the tank sufficient to overcome all irregular shapes or unstable conditions as described in API Standard 2555 (ASTM D1406).

2.2A.16.5 For tanks operated with the bottom completely and continuously covered with water, any slope or irregularity, but not instability, of the bottom may be disregarded.

2.2A.16.6 An alternative method of calibrating the bottom zone is by taking level elevations at various points along the bottom through a bottom survey. A physical bottom survey of the tank bottom should be made, whenever possible, after the tank has been hydrotested, in order to establish the amount of slope from the tank shell to the tank center. The elevation at the strike point directly under the gauging hatch should also be measured.

2.2A.16.7 Due to the nature of some bottoms being very irregular, survey readings should be taken at many points to better determine the shape. When performing a complete bottom survey, elevations should be sighted along radii every 45 degrees. Along these radii, obtain elevations at equally spaced intervals not more than 10 feet (or 3 meters) from the tank's center to its shell.

2.2A.17 Floating Roofs

2.2A.17.1 GENERAL

Floating roofs, illustrated in Figures 15 and 16, are installed in tanks with upright cylindrical shells. Floating

roof displacement, however, gives rise to special deductions for floating weight and deadwood. Position A (see Figure 15), is the liquid level at which the liquid first touches the contact deck of the roof. Position B is the liquid level at which the last support of the roof lifts free of the tank bottom and the roof is fully buoyant.

2.2A.17.2 FLOATING ROOF WEIGHT

When a roof is fully buoyant, it displaces an amount of liquid equal in weight to the floating weight of the roof. The floating weight should include the roof plus any appurtenances that are carried up and down in the tank with the roof, including fifty percent of the weight of the stairway. The roof weight is calculated by the builder and should be reported by the strapper.

2.2A.17.3 DEADWOOD DETERMINATION

When all or part of the weight of a roof is resting on the roof supports, the roof and all appurtenances should be deducted as deadwood as they become immersed in liquid. Deadwood includes such parts as the swing joint, the drain, and other items that are attached to the tank shell or bottom. Since a swing pipe is normally full of liquid, only the metal volume is deadwood. On the other hand, a closed drain is normally empty, and the total pipe or hose volume is included as deadwood. Deadwood also includes parts that eventually move with the roof. The roof itself is deadwood, and as the liquid level rises around the roof, its geometric shape determines how it should be deducted. The geometric shape should be taken from the builder's drawings or measured in the field while the roof is resting on its supports.

2.2A.17.4 DEDUCTING FLOATING ROOF DISPLACEMENT

Two methods of deducting floating roof displacement from capacity tables are as follows:

- a. Liquid calibration.
- b. Mathematical calculation of roof displacement (see Appendix B).

2.2A.18 Insulated Tanks

The following procedures may be used in determining the data necessary for the preparation of capacity tables. Calibration of outside insulated tanks may be completed before the insulation is applied by following the procedures for outside measurements specified in this standard for above ground tanks of the same type. If the tank is insulated, the following procedures apply. Alternate procedures, however, may be applied as here indicated:

- a. Liquid Calibration: Insulated tanks may be calibrated by the introduction of measured quantities of liquid in accordance with API Standard 2555 (ASTM D 1406).




Figure 13—Spherical Segment (Dished), Hemispherical and Semiellipsoidal Bottoms Convex and Accessible Measurements of Upright Tanks





Figure 14—Coned Downward Bottom and Accessible Measurements of Upright Tanks

b. Calibration Based on Inside Measurements: Calibration of insulated tanks may be based on inside measurements by application of API Chapter 2.2B.

c. Calibration Based on Drawings: Calibration may be based on the data given in the drawings and in the specifications of the tank builder if none of the preceding methods can be used. This alternative is the least preferred method and is not recommended for tanks used for custody transfer.

d. Application of New Technologies: New technologies such as optical triangulation method, electro optical distance ranging (EODR method) are described under Appendix F.

2.2A.19 Tank Capacity Table Development: Calculation Procedures

Sound engineering and mathematical principles should be used in all calculations for development of capacity tables. These principles should include those given herein for application to this particular type of work:

a. The capacity tables should be prepared at 60°F (15°C) and should take into account liquid head stress correction, deadwood, tilt correction, and if applicable floating roof allowance.

Note: Even though the base temperature of the tanks is 60°F (or 15°C), the liquid density used in calculating the liquid head stress correction and floating roof allowance should be the average observed density for that given tank.

b. For temperature allowance, the temperature expansion factor should be applied as a separate factor (see Appendix D).

c. All incremental or total volume calculations should be carried to seven significant figures. (Refer to Appendix C for Guidelines for Computer Input.)

d. All deadwood should be accurately accounted for as to volume and location, in order to permit adequate allowance for volumes of liquid displaced by various objects or appurtenances and the allocation of these effects at various elevations within the tank.

e. The preparation of capacity tables for upright tanks is based on a maximum liquid height not greater than the shell




Figure 15—Diagram of Floating Roof at Rest (A) and Floating (B)

height. The volume within the tank which is above that level shall be disregarded in capacity tables. An example of this disregarded volume is the space under a cone roof down to the level of the top edge of the top ring.

f. Tank capacities should be expressed in gallons, barrels, cubic meters, liters or other (Tables 5 and 6 and Appendix B).

g. Each item on the strapping report is evaluated for accuracy before processing.

h. As a matter of principle, it is recommended that all newly prepared capacity tables show thereon the date on which they are effective. The basis for establishing such a date, in specific cases, is dependent upon individual circumstances and the needs of the parties concerned. However, it is intended that the effective date be established, taking into consideration circumstances including, but not limited to, the following:

1. The date a new tank was first calibrated.
2. The date an old tank was recalibrated.
3. The date the tank was recomputed.

2.2A.19.1 CAPACITY TABLE REQUIREMENTS

The following parameters must be considered for the development of capacity tables.

- a. Expansion and contraction of steel tank shell due to liquid head (see 2.2A.19.5).
- b. Expansion and contraction of steel tank shell with temperature [recommended to be applied independent of capacity table computations (see 2.2A.19.6)].
- c. Tilt from a vertical position (see 2.2A.19.7).
- d. Tank bottoms that are irregular in shape (see 2.2A.16).
- e. Effective inside tank height (see Figure 12).

2.2A.19.2 CALIBRATION OF THE MASTER TAPE TO 60°F

2.2A.19.2.1 The master tape for calibrating tank measuring (working) tapes shall be identified with a Report of Calibration at 68°F by the National Institute of Standards and Technology (NIST) attesting to the master tape accuracy within 0.001 foot (approximately $\frac{1}{4}$ inch, 1 millimeter resolution and read to the nearest 0.5 millimeter) per 100 feet of length. The Report of Calibration shall include the factors and formulas necessary to correct tape length for use at 60°F (15°C) under tension differing from that used during calibration.

2.2A.19.2.2 The petroleum industry uses 60°F (or 15°C) as a standard temperature for petroleum products. The master tape should be corrected to this temperature using the following equation:

$$\begin{aligned}\text{Correction Factor} &= 1 + [(T_s - T_c) \times C] \\ \text{Correction factor} &= 1 + [(60 - 68) \times 0.00000645] \\ &= 1 + (-8 \times 0.00000645) \\ &= 0.9999484\end{aligned}\quad (1)$$

Where:

- T_c = Calibration Temperature of master tape (normally 68°F).
 T_s = Standard reference temperature (normally 60°F).
 C = Coefficient of expansion for mild steel 0.00000645 FT/FT/Degree Fahrenheit.

2.2A.19.3 CONVERSION OF OUTSIDE TO INSIDE CIRCUMFERENCES

Plate thicknesses used in calculations should be those reported on field measurement records. Where possible, thickness should be measured by ultrasonic thickness method. Values for plate thicknesses taken from drawings may be used where necessary.

$$\text{Inside Circumference} = \pi \times (D - 2t) \quad (2)$$

Where:

- t = steel thickness.
 D = outside diameter, both in consistent units.

2.2A.19.4 DEDUCTIONS FOR CIRCUMFERENCE TAPE RISES

2.2A.19.4.1 In the event that the tape is prevented from being in contact with the tank shell at all points along its path by projections from the tank shell, such as butt straps or lap joints, the amount of increase in circumference due to tape rises at such projections should be determined. Circumferences as measured on a given ring should be corrected by deducting the sum of the increases in circumference at each tape-rise location.

2.2A.19.4.2 Deduction for tape rise may be computed from the tape-rise correction Equations 3 and 5 in 2.2A.19.4.3 and 2.2A.19.4.4, or measured with a caliper where practical to do so. Due to the very small correction for tape rise at a low projection, such as a lap joint or butt strap, it is impractical to measure accurately the correction with a caliper; therefore, the tape-rise correction method is preferred for such projections.

2.2A.19.4.3 The Tape-Rise Correction Equation for Butt Straps or Similar Projections is as follows:

$$\text{Deduction (inches)} = \frac{2Ntw}{d} + \frac{8Nt}{3} \sqrt{t/d} \quad (3)$$

Where:

- N = number of butt straps or projections per ring.
 t = amount of rise (thickness of straps or projections), in inches.
 w = width of straps or projections, in inches.
 d = nominal diameter of tank, in inches.

Table 5—Customary Version Capacity Table
Example Capacity Table—Tank No. 117 Floating Roof

CAPACITIES GIVEN IN WHOLE BARRELS OF 42 US GALLONS
 MAXIMUM SAFE FILL HEIGHT = 4'5" 3/4" DUE TO OVERFLOW
 GAUGE HEIGHT = 48" 6 3/8"

[illegible]

A total of 18.97 barrels has been deducted from this table between 3'-6" and 3'-10" for roof displacement based upon a floating weight of 4,900 lbs. and observed API gravity of 60.0. Gauged levels above 3'-10" reflect this deduction. For gravities other than 60.0 API/observed adjust quantities about 3'-10" as follows. Add 0.10 barrels per degree below 60.0 API/observed. Subtract 0.10 barrels per degree above 60.0 API/observed

1) A 3/8" crown has been deducted from the first 4' of capacity table.	Strapped by: WS-SL 5/19/92
2) Tank strapped and computed in accordance with API MPMS Chapter 2.2A.	Computed by: MH 5/19/92
3) Liquid head stress has been applied to table at API gravity 60.0.	Checked by: MH 5/19/92
4) For precise fractional values, interpolate between incremental volumes.	
5) Capacity table stops at 45'-5 1/2" due to overflow.	
6) Nominal tank diameter = 67'-0", shell height = 48'-0".	

2.2A.19.4.4 The Tape-Rise Correction Equation for Lap Joints is as follows:

a. Application of Equation 3 in modified form to tape rise at lapjoints is described with reference to Figure 17. In Figure 17, the locations of the plates in the lap joint are shown as positioned by the plates in the rings above and below the lap joint. The position of the plate in the ring if no joint existed is shown by the broken lines in relation to the plates in the lap joint.

b. The circumference as measured over the lap joint should be corrected to the true circumferential path the tape would take if no joint existed. As shown in Figure 17, this requires correction for only one-half of the tape rise. With the width, w , eliminated, the equation becomes:

$$\text{Deduction (inches)} = \frac{8N}{3} \times \frac{t}{2} \times \sqrt{t/2d} \quad (4)$$

$$= \frac{4Nt}{3} \times \sqrt{t/2d} \quad (5)$$

c. It is also shown in Figure 17 that no deductions for deadwood at lap joints are required, since the deductible and additive volumes at lap joints are equal.

2.2A.19.5 EXPANSION AND CONTRACTION OF STEEL TANK SHELLS DUE TO LIQUID HEAD

2.2A.19.5.1 Expansion and contraction of steel tank shells due to liquid head shall be taken into consideration.

This adjustment need not be made for tanks with a capacity of less than 500 barrels.

2.2A.19.5.2 The effect of liquid head may be introduced into the capacity table in the following ways:

a. Reduce strapped circumferences to zero stress condition by using equation 6 (see 2.2A.19.5.3) and by applying expansion effects of progressively increasing liquid levels at successive course levels.

b. By strapping the tank with maximum liquid level and destressing the tank by courses for decreasing liquid levels.

2.2A.19.5.3 Field circumference measurements shall be adjusted to "empty tank" or unstressed basis. Then the volume calculations should proceed with volumes adjusted to show progressively increasing capacity, including expansion effects, at successively higher levels by rings. Strapped circumferences should be corrected to zero stress condition by means of the following equation:

$$\Delta C = \frac{-WhC^2}{2\pi Et} \quad (6)$$

Where:

ΔC = circumference correction to empty tank or unstressed condition.

W = weight of liquid per unit volume.

h = liquid head above strapped elevation.

C = strapped circumference before correction.

E = modulus of elasticity of metal in tank shell.

t = shell thickness at strapped elevation.

Note: All units must be consistent. For example, in the customary system, ΔC , C , h , and t may be in inches; W , in pounds per cubic inch; and E in




Figure 16—Typical Steel Pontoon Floating Roof with Single Center Deck




Figure 17—True Circumference Versus Tape Path at Axial Lap Joint Away from Circumferential Joint

pounds per square inch. The corrected strapped circumference is then stressed to a "ring full" basis by expanding the unstressed circumference for each ring by the height of liquid above the circumferential elevation necessary to fill each ring.

Volume Correction per increment, Δv :

$$\Delta v \text{ (first, or bottom ring)} \quad (7A)$$

$$= 0$$

$$\Delta v \text{ (second ring)} \quad (7B)$$

$$= \frac{\pi W d^3}{4E} \left(\frac{h_1}{t_1} \right)$$

$$\Delta v \text{ (third ring)} \quad (7C)$$

$$= \frac{\pi W d^3}{4E} \left(\frac{h_1}{t_1} + \frac{h_2}{t_2} \right)$$

$$\Delta v \text{ (nth ring)} \quad (7D)$$

$$= \frac{\pi W d^3}{4E} \left(\frac{h_1}{t_1} + \frac{h_2}{t_2} + \dots + \frac{h_{n-1}}{t_{n-1}} \right)$$

Where:

Δv = additional tank volume resulting from tank shell expansion due to increased head of an increment one unit deep above the ring.

W = weight of liquid per unit volume.

d = nominal tank diameter.

E = modulus of elasticity of metal in tank shell.

$h_1, h_2, \text{ etc.}$ = height of shell rings.

$t_1, t_2, \text{ etc.}$ = thickness of shell rings.

Note: All units must be consistent. For example, in the Customary Units, Δv may be in cubic inches; W , in pounds per cubic inch; d, h , and t , in inches; and E , in pounds per square inch. The increment corresponding to Δv is 1 inch. If the capacity table is made in $\frac{1}{4}$ -inch increments, Δv must be divided by 4.

2.2A.19.6 EXPANSION AND CONTRACTION OF STEEL TANK SHELLS DUE TO TEMPERATURE

2.2A.19.6.1 Expansion and contraction of unheated steel tank shells should be calculated. It may be necessary to estimate the service temperature and compute volume corrections for expansion of the tank shell due to the increase in temperature. Such estimates of temperature should be checked after tanks are in service. The correction procedure for computing the volume to be added to the total volume calculated for the tanks from strapping in the unheated conditions is as follows:

Cross-sectional area correction,

$$K = 1 + 12.4 \times 10^{-6} \Delta T_s + 4.0 \times 10^{-9} \Delta^2 T_s \quad (8)$$

Where:

ΔT_s = Tank shell steel temperature minus 60°F. (All tank strapping circumference measurements for steel tanks are at 60°F.)

2.2A.19.6.1.1 For noninsulated metal tanks, the temperature of the shell may be computed as follows (refer to Appendix D):

$$T_s = [(7 \times T_L) + T_a] \div 8 \quad (9)$$

Where:

T_L = liquid temperature.

T_a = ambient temperature.

2.2A.19.6.1.2 For insulated metal tanks, the temperature of the shell may be taken as closely approximating the adjacent liquid temperature, in which case, $T_s = T_L$.

2.2A.19.6.2 In applying these principles to upright cylindrical tanks, the horizontal cross-sectional area may be taken as a function of tank calibration. The coefficient determined from Equation 8 (see 2.2A.19.6.1) is predicated on a thermal expansion for low-carbon steel per degree Fahrenheit.

Note: The cross sectional correction (Equation 8) will have to be modified for stainless steel tanks based upon the coefficient of expansion for the type of stainless steel.

2.2A.19.6.3 The third dimension, height, needed to generate volume is a function of gauging and should be considered separately. The volumes reflected on tank tables are derived from area times incremental height. Therefore, K -factors for correction of areas have the same ratio as volume corrections and may be applied directly to tank table volumes.

2.2A.19.6.4 The shell temperature correction factor is to be applied to volumes obtained from capacity tables that are at 60°F and are unrelated to the corrections designed to account for volume expansion and contraction of the product itself. Depending upon certain requirements, this shell temperature correction factor may be built into the capacity table for a specific operating temperature.

2.2A.19.6.5 With application of on-line computers, the temperature correction factor can be continuously updated to reflect varying liquid and ambient conditions. Such an updated factor may then be used to determine the actual volume in the tank (refer to example calculation in D.2 of Appendix D).

2.2A.19.7 EFFECT OF TILT ON CYLINDRICAL PORTION OF TANK

2.2A.19.7.1 The amount of tilt in shell height should be measured. For tanks tilted less than 1 part in 70 parts, the error in a vertical capacity table for the cylindrical portion will be less than 0.01 percent by volume and the effect may be disregarded. If the amount of tilt is 1 in 70 or more, the vertical capacity table should be adjusted to a zero-tilt basis. The following equation may be used to determine the percentage volume correction due to tilt:

$$\text{Volume Correction, percent} = 100 \left(\sqrt{1 + m^2} - 1 \right) \quad (10)$$

Where:

m = amount of tilt per foot of shell height, in feet (or decimal part thereof).

2.2A.19.7.2 The following tabulation shows the volume correction in percent for various amounts of tilt:

Tilt, Feet per 100 Feet	Volume Correction, percent
1.4	+0.0098
1.6	+0.0128
1.8	+0.0162
2.0	+0.0200
2.2	+0.0242
2.4	+0.0288
2.6	+0.0338

2.2A.19.8 FLOATING ROOFS

The capacity table should be prepared on the basis of gauging from the striking point upward to the liquid level in the gauge hatch. The preparation of the gauge table is related to the method used for obtaining field data in the zone of partial displacement, that is, whether liquid calibrated or linear measured (see 2.2A.17).

2.2A.19.8.1 Liquid Calibration for Floating Roof Displacement

2.2A.19.8.1.1 The displacement of a floating roof through the critical zone, A to B (see Figure 15), is most accurately determined by liquid calibration, as presented in API Standard 2555 (ASTM D 1406). Following this procedure will result in a gauge table with the floating roof treated as deadwood. This type of gauge table is more fully described in 2.2A.19.8.2.

2.2A.19.8.1.2 Above Position B (see Figure 15) capacities should be corrected to account for the change in roof displacement resulting from the difference between the density of the calibration liquid and that of the liquid being gauged. It is convenient to correct the table to an assumed particular API gravity near that of the average liquid that will be handled in the tank. This correction should be computed as follows:

$$\text{Correction (gallons)} = W \left(\frac{1}{p_c} - \frac{1}{p_a} \right) \quad (11)$$

Where:

W = floating weight of roof in pounds
 p_c = pounds per gallon of the calibration liquid
 p_a = pounds per gallon of a liquid having the assumed particular API gravity on which the table is based.

2.2A.19.8.1.3 After correction to an assumed API gravity, the table is accurate only if at time of gauging the API gravity at the tank liquid temperature is the same as the API gravity for which the table is prepared. Usually the API

gravity is different, and it is therefore necessary to correct a volume taken from the table. This correction is described in 2.2A.19.8.4.

2.2A.19.8.2 Measurement Procedure for Floating Roof Displacement

2.2A.19.8.2.1 Liquid Level below Position A in Figure 15: This range can be accurately calibrated by measurements as described in 2.2A.8 through 2.2A.14.2. All deadwood must be deducted.

2.2A.19.8.2.2 Liquid Level Between Positions A and B in Figure 15: This range cannot be accurately calibrated by measurements described in 2.2A.8 through 2.2A.14.2. The upper and lower limits should be clearly indicated on the gauge table with a note stating that this range should be avoided for critical measurements.

2.2A.19.8.2.2.1 In calibrating this range by the measurement procedure (see Appendix B), all deadwood, including the geometric shape of the roof, should be deducted. This should be carried up to position B, the location of which must be determined by the calculator.

2.2A.19.8.2.2.2 Since the shape of the roof changes between Position A and Position B, it is necessary to take an arbitrary distribution of roof displacement to make the roof displacement at position B equivalent to the floating weight.

2.2A.19.8.2.2.3 Since the displaced volume of liquid is contingent upon an assumed specific gravity of liquid to be handled in the tank, and since the shape of the roof and tank bottom may change with time, it is advisable to allow 2 inches (or 50 millimeter) of depth below position A and above position B in establishing the critical zone. This allowance does not influence any calculation but only the upper and lower limits of the critical zone indicated on the gauge table.

Note: An accuracy problem often encountered when a roof position is measured is that the roof will be in the high position for maintenance. Often, when the tank is returned to service, the roof legs are adjusted to the low position. This action will create errors in the capacity table if it is computed and issued with the roof in the high position. The quantities from the start of the low position to the end of the high position of the roof critical zone will be in error. To ensure the accuracy of the floating roof capacity table, it is necessary to confirm the operational roof position with the tank operator or owner before development of the capacity table.

2.2A.19.8.3 Liquid Level Above Position B

The liquid level above position B (see Figure 15) range can be accurately calibrated by subtracting a volume of liquid equal in weight to the floating weight. The floating weight should include the roof plus any appurtenances that are carried up and down in the tank with the roof. The floating weight is calculated by the builder and given on the drawings and on the roof nameplate. The floating weight should include half of the ladder weight, half of the weight

of the hinged or flexible supported parts of the drain, all of the swing line float, and half of the swing pipe. Above position B, deadwood which is now included as part of the floating weight should be added back in to the gross or open-tank capacity and thereafter accounted for by the floating-weight deduction. Deadwood not included in the floating weight is retained in the gross capacity.

2.2A.19.8.4 Capacity Table with Floating Roof Treated as Deadwood

2.2A.19.8.4.1 In this type of gauge table, the weight of the floating roof should be taken into account by reducing the gross capacity by the volume displaced by the roof based on an assumed API gravity near that of the average liquid that will be handled in the tank.

2.2A.19.8.4.2 For liquid levels below position B, Figure 15, all deadwood should be deducted as it becomes immersed. This deadwood should include the floating roof, itself, based on its geometric shape.

2.2A.19.8.4.3 For values above position B, Figure 15, the gross volume should be reduced by a volume equal to the floating weight divided by the weight per unit volume of a liquid having an assumed API gravity. These net values are given directly in the gauge table. They are correct only if at the time of gauging the API gravity at tank liquid temperature is the same as the assumed API gravity for which the table is prepared.

2.2A.19.8.4.4 Usually, the API gravity at tank liquid temperature is different from the assumed API gravity on which the table is based. It is, therefore, necessary to include a supplementary correction to the capacity table. This correction is equal to the following:

Correction (units of volume per degree API) =

$$\frac{W}{50} \left(\frac{1}{p_{60}} - \frac{1}{p_{10}} \right) \quad (12)$$

Where:

- W = floating weight of roof, in pounds.
- p_{60} = pounds per gallon of a liquid having a 60-degree API gravity.
- p_{10} = pounds per gallon of a liquid having a 10-degree API gravity.

2.2A.19.8.4.5 The API gravity correction should be handled by a note on the capacity table requiring the deduction or addition of a constant volume for each degree API gravity difference from the assumed API gravity for which the basic capacity table was prepared. This note should contain the following information:

"Note: A total of ___ bbl has been deducted from this table between ___ feet ___ inches and ___ feet ___ inches

for roof displacement based on a floating weight of ___ pound and an observed liquid gravity of ___°API as observed under conditions of the liquid in which the roof is floating. [This may be at any observed temperature.] Gauged levels above ___ feet ___ inches reflect this deduction but should be corrected for actually observed gravity of the liquid at prevailing temperatures as follows:

For ___°API observed, no correction.

For each degree below ___°API observed, add ___ bbl.

For each degree above ___°API observed, subtract ___ bbl."

2.2A.19.8.5 Capacity Table of Gross or Open-Tank Capacity

2.2A.19.8.5.1 This type of capacity table is prepared by deducting only the deadwood not included as part of the floating weight. A supplementary table accounting for all deadwood may be prepared and included as a supplement to the capacity table for all positions up to position B, Figure 15.

2.2A.19.8.5.2 For use above position B, Figure 15, the floating weight should be given on the capacity table. In using the capacity table, the gross or open tank volume is reduced by a volume equal to the floating weight divided by the weight per unit volume of the liquid. The weight per unit volume should be based on a density at 60°F (or 15°C) consistent with the liquid in the tank. Also, the weight per unit volume must be based on the same temperature as the gross volume from which the roof displacement will be subtracted.

2.2A.19.8.5.3 When using the capacity table, it is convenient to first convert the gross volume to a standard temperature, usually 60°F (or 15°C). Then, the floating weight is divided by the weight per unit volume at 60°F (or 15°C) before subtracting from the gross volume. When this is to be done, a supplementary table may be prepared giving values of the displacement for a range of values of the API gravity over which the tank is intended to be used.

2.2A.19.8.5.4 When applicable, the following notation shall be included on all gauge tables which are prepared for the open or shell capacity of floating-roof tanks:

"The quantities listed on this capacity table do not include adjustments to compensate for floating-roof displacement."

2.2A.19.8.5.5 All capacity tables for floating roof tanks should have the limits of the zone of partial displacement clearly marked thereon. A note on the capacity table should state whether this zone was calibrated by liquid calibration or by the measurement method.

2.2A.19.9 SUMMARY DATA ON THE CAPACITY TABLE

The final capacity table should contain the following information:

- a. Tank ID.
- b. Product name and gravity at 60°F (or 15°C).
- c. Type of tank (Floating Roof, Cone, Insulated, etc.).
- d. Floating roof deadweight.
- e. Whether recomputed/recalibrated.
- f. If recomputed, basis for recomputing.
- g. Reference gauge height, maximum fill height, and maximum safe height.
- h. Description/location of reference gauge point.
- i. Cone up/cone down/flat bottom.
- j. It should be noted on the capacity table that the volume below the striking point, whether determined by linear or liquid calibration, is included in the first increment.
- k. Temperature at which the capacity table is computed if integral to the table. It is recommended the capacity table be computed at 60°F (or 15°C) and temperature correction factors be applied externally.
- l. Contractor company's name.
- m. Date of Calibration/Recalibration/Recomputation.
- n. Standard on which calibration is based.

2.2A.19.10 RECALIBRATION REQUIREMENTS

2.2A.19.10.1 Storage tanks may require recalibration/recomputation periodically. The factors impacting the

frequency of recalibration and/or recomputation are described in Appendix A.

2.2A.19.10.2 However, vertical or upright tanks should in any case be remeasured and calibrated under the following conditions:

- a. When restored to service after being disconnected or abandoned.
- b. When disassembled and re-erected or when "moved bodily."
- c. When deadwood is changed, when concrete or other material is placed on the tank bottom or on the shell of the tank, or when the tank is changed in any manner which would affect the incremental or total volume.

2.2A.19.11 CERTIFICATION OF CAPACITY TABLES

2.2A.19.11.1 Certification of a capacity table ensures that all measurements and computations are performed in accordance with this standard. It is recommended that this certification be performed by recognized contractors in the specialized field of calibration or by person or persons who can demonstrate their compliance with this standard.

2.2A.19.11.2 In the process of certification, it is the responsibility of the contractor and/or individual and tank owners to clearly document and specify any deviations from the standard. Any deviations from the standard that result in nonconformity with the standard renders the capacity table unsuitable for custody transfer usage.

APPENDIX A— GUIDELINES FOR RECALIBRATION OF STORAGE TANKS

A.1 Introduction

This guideline is intended to provide a general frame work and a technical basis to enable terminal operators and tank owners to make sound decisions relating to the frequency of verification and recalibration of storage tanks. The differentiation between recomputation (of capacity table) and recalibration is also discussed together with the factors that impact the same.

A.2 Terminology

A.2.1 *Recomputation* (of the capacity table) is the process of development of a revised capacity table, based on previously established tank diameters.

A.2.2 *Recalibration* (also referred to as *re-strapping*) is the process of re-establishing tank diameters through physical measurements and of developing a new capacity table based on these tank diameters.

A.3 Factors Impacting Recomputation

Recomputation should be considered when operating variables of the storage tank change. These variables are product temperature, specific gravity of product contained within the tank, and the reference gauge height.

A.4 Factors Impacting Recalibration

A.4.1 Recalibration should be considered when internal dimensions and structural variables of the tank change. The measurement variables include reference gauge height, tank diameter, tank plate thickness, and tilt.

A.4.2 The structural variables include changes in tank deadwood, reference gauge height, tank structure (both internal and external including floating roof), and repairs to tank and tank bottom (bottom replacement).

A.5 Acceptable Overall Volume Variability and Criteria Tables

A.5.1 In order to establish acceptance limits of variation on measurement and operating variables, a determination must be made as to what is the overall variability in tank volume that could be considered significant. Such a determination may be made using criteria tables.

A.5.2 Tables A-1, A-2, and A-3 provide criteria tables for recalibration while Tables A-4 and A-5 provide criteria tables for recomputation. Included in the allowable variation in diameter is a permissible average measurement error of 6 millimeters on circumference in the strapping of the bottom course of the tank.

Table A-1—Tank Bottom Course Inside Diameter Variations

Approximate Variation in Basic Volume, %	Nominal Tank Diameter, ft, Up To:					
	50	100	150	200	250	300
	Allowable Variations in Diameter, mm ^a					
0.01–0.02	3	4	4	5	6	7
0.02–0.03	4	5	7	9	10	12
0.03–0.04	4	7	10	12	15	18
0.04–0.05	5	9	12	17	20	24
0.05–0.06	6	10	15	20	25	30

^aTank diameter is the zero stress inside diameter.

Table A-2—Tank Bottom Course Plate Thickness

Nominal Tank Diameter, ft	Plate Thickness Variations, mm ^a
50–300	1.5–3

^aPlate thickness measured at 8 points circumferentially on the bottom course and averaged.

Table A-3—Volume Correction for Tank Tilt

Tilt ft/100 ft	Volume Correction Factor, %	Remarks
1.4	0.010	• Measure tilt at the same location • Compute variability in volume based on the initial and final tilt
1.6	0.013	
1.8	0.016	• Maximum tilt variation 0.024% allowable, vol %
2.0	0.020	
2.2	0.024	
2.4	0.029	• A variation of 0.005% due to tilt should be considered significant and should warrant recalibration
2.6	0.034	

Table A-4—Tank Shell Temperature Variations

Variation in Shell Temp. T_s , °F	Variation in Ambient Temp. T_a , °F	Variation in Liquid Temp. T_L , °F	Approximate Variation in Volume, %
9	72	10	0.01
18	145	20	0.03
35		40	0.04
70	—	80	0.07

Note: Shell temperature (T_s) can vary either due to variation in liquid temperature (T_L) or due to variation in ambient temperature or both. The values tabled correspond to variations either in T_a or T_L for uninsulated tanks. For insulated tanks, variation in T_s will be equal to the variation in T_L . Variation in ambient temperature in excess of 145°F is not considered. Ambient temperature has no effect on the shell temperature for insulated tanks.

Note: Table A-4 is updated from original publication due to usage of New Shell Temperature Correlation.

Table A-5—Product Specific Gravity Variations

Variation in Specific Gravity %	Approximate Variation in Volume % ^a
10	0.008–0.015
20	0.015–0.030
30	0.030–0.040
40	0.040–0.050
50	0.050–0.065

^aActual variation in hydrostatic head correction volume could be higher than specified, depending on tank plate thickness.

A.6 Guidelines for Recalibration: Measurement Variables^{A-1}

A.6.1 For tanks in custody transfer service, verification of the bottom course diameter, bottom course plate thickness, and tank tilt is suggested once every five years. If any of these three parameters (diameter, thickness, and tilt) exceed the criteria for a predetermined variation in volume (see Tables A-1, A-2, and A-3), a total recalibration should be considered. These variations in tank inside diameter should be computed after de-stressing the measured diameter to a zero stress condition using correlations presented in 2.2A.19.5.

A.6.2 For tanks not in custody transfer service, verification of the measurement variables (diameter, thickness of bottom course, and tilt) may be considered once every five to ten years. If any of these variables exceed the criteria for a pre-established variation in volume (see Tables A-1, A-2, and A-3), a total recalibration should be considered.

A.6.3 Tanks do change with time and service, and volume changes may not be readily identified by visual inspection or the preceding verification procedures. Because of that, it is considered justifiable practice to recalibrate tanks on a periodic basis to reassure good measurement accuracy. A total recalibration at 15 year intervals for tanks in custody transfer service and at 15–20 years for others is reasonable.

A.6.4 The tank owners may increase or decrease recalibration frequencies based on the evaluation of historical data, field tests and performance records. It is recommended that such an evaluation be based on sound engineering principles and generally consistent with the criteria tables presented herein.

A.7 Guidelines for Recalibration: Structural Variables

The following is a list of guidelines for recalibration considering structural variables:

- If there is a change in the deadwood that impacts the tank volume by a preset value (for example, 0.02 percent), a recalibration should be considered.
- If alterations to the tank shell are undertaken, door sheets cut out and replaced, overflow vents cut out and any

rewelding, a recalibration may be required.

c. If the reference gauge height is altered by modifications to the datum plate or rewelding or resupporting of the datum plate, a recalibration may be required.

d. If any repair work to the floating roof could alter floating roof deadweight which in turn could alter tank volume by a predetermined value (for example, 0.02 percent), a recalibration should be considered.

e. If major repair work to the tank bottom plate is undertaken, a total recalibration should be considered along with a bottom survey.

A.8 Guidelines for Recomputation

A.8.1 Two major variables that impact recomputation of the tank capacity table are the tank shell temperature (T_s) and the gravity of the product stored within the tank. In addition, reference gauge height variation will affect recomputation under circumstances.

A.8.1.1 A variation in liquid temperature (T_L), ambient temperature (T_a), or both will impact the net tank shell temperature (T_s). For a pre-selected allowable volume variation, Table A-4 provides allowable shell temperature variation (using New Correlation, see 2.2A.19.6.1.1) and corresponding variation in liquid or ambient temperature. Under these circumstances, a recomputation of the capacity table should be considered.

A.8.1.2 Table A-5 provides criteria for gravity variations. Using Table A-5 depending on the allowable volume variation, the allowable specific gravity variation can be determined. A recomputation of the capacity table for the new specific gravity should be considered using Table A-5.

A.8.2 If the reference gauge height is altered by modifications to the datum plate or rewelding or resupporting of the datum plate, a recomputation may be required.

A.8.3 If any repair work to the floating roof could alter floating roof deadweight which in turn could alter tank volume by a predetermined value (for example, 0.02 percent), a recomputation should be considered.

A.9 Development of Capacity Table

To facilitate recomputation, it is suggested that the tank capacity table be developed in three distinct parts:

- Part 1: Basic capacity table at 60°F including hydrostatic head correction and deadwood corrections.
- Part 2: Shell temperature expansion factor table in increments of 5°F.
- Part 3: Floating roof correction table. Recomputation may be required for any or all of the three parts (1, 2 and 3) of the table depending on the variables.

^{A-1}Reproduced in part and based on S. Sivaraman and B.J. Hampton, "Guidelines Set for Recalibration of Storage Tanks," *Oil & Gas Journal*, June 12, 1989, Technology Issue.

APPENDIX B—EXAMPLE CALCULATIONS FOR UPRIGHT CYLINDRICAL STEEL TANK—ABOVEGROUND

B.1 Circumference Corrections

B.1.1 CORRECTION OF CIRCUMFERENCES: WORKING TAPE VS. MASTER TAPE

See Figure B-2.

Master tape at 10 pounds tension = 100.0026 feet per 100.0 feet measured

$$\frac{100.0026}{100.00 \text{ feet}} \approx \frac{X}{210.68 \text{ feet}} \quad ; \quad X = 210.6855 \text{ feet}$$

Corrected Master Tape Measurement at 68°F

B.1.2 TEMPERATURE CORRECTION FROM 68°F TO 60°F

See Figure B-2.

(68° - 60°) = 8°F difference $\times$ 0.00000645 coefficient of expansion

$$1.0 - (8 \times .00000645) = 0.9999484$$

$0.9999484 \times 210.6855 = 210.6746 \text{ ft.}$ Corrected Master Tape Measurement at 60°F

210.6900 ft.	Working Tape Circumference
<u>-210.6746 ft.</u>	Master Tape Circumference
-0.0154 ft.	Correction made to each working tape circumference

B.1.3 DEDUCTION FOR CIRCUMFERENCE TAPE RISE

See Table B-2.

Tape rise correction for circumference A and B due to measurement taken over Butt Straps,

$$\text{in feet} = \left[\frac{2NtW}{d} + \frac{8Nt}{3} \sqrt{\frac{t}{d}} \right] \div 12$$

Where:

- N = number of butt straps per ring.
- t = amount of rise (thickness of straps), in inches.
- W = width of straps, in inches.
- d = nominal diameter of tank, in inches.

$$\text{Correction}_A = \left[\frac{2 \times 14 \times 1 \times 13}{804} + \frac{8 \times 14 \times 1}{3} \sqrt{\frac{1}{804}} \right] \div 12 = 0.1474 \text{ feet}$$

$$\text{Correction}_B = \left[\frac{2 \times 14 \times 0.75 \times 10}{804} + \frac{8 \times 14 \times 0.75}{3} \sqrt{\frac{0.75}{804}} \right] \div 12 = 0.0930 \text{ feet}$$

Tape rise correction for circumference C through F due to measurement taken over lap joint

$$= \left[\frac{4Nt}{3} \times \sqrt{\frac{t}{2d}} \right] \div 12$$

$$\text{Correction}_C = \left[\frac{4 \times 14 \times 0.3125}{3} \sqrt{\frac{0.3125}{2 \times 804}} \right] \div 12 = 0.0068 \text{ feet}$$

$$\text{Correction}_D = \left[\frac{4 \times 14 \times 0.25}{3} \sqrt{\frac{0.25}{2 \times 804}} \right] \div 12 = 0.0048 \text{ feet}$$

$$\text{Correction}_E = \text{Correction}_D \quad - \text{same} = 0.0048 \text{ feet}$$

$$\text{Correction}_F = \text{Correction}_D \quad - \text{same} = 0.0048 \text{ feet}$$

B.1.4 CORRECTION OF MEASURED CIRCUMFERENCES TO EMPTY TANK BASIS

See Table B-2 and Figure B-1.

$$\text{Correction for circumferences} = -\frac{WhC^2}{2\pi Et}$$

Where:

- W = weight of liquid, in pounds per cubic foot.
- h = height of liquid, in feet.
- C = measured circumference, in feet.
- E = modulus of elasticity of steel (29,000,000 psi).
- t = thickness of steel, in inches.

$$\text{Or more conveniently expressed as: } -K \frac{GhC^2}{t}$$

Where:

$$K = \frac{62.3}{24\pi E} = 0.00000002849239.$$

$$G = \text{observed specific gravity of liquid in tank (1.0 in this example).}$$

Correction_A = no correction. On riveted tanks, the circumference at the bottom of the first ring does not expand or contract in a magnitude equal to that reflected by the formula. It is recommended that the formula not be applied to this circumference.

$$\text{Correction}_B = K \left(\frac{1 \times 31.2917 \times (210.6496)^2}{0.4375} \right) = 0.0904 \text{ feet}$$


$$\text{Correction}_C = K \left(\frac{1 \times 23.3334 \times (210.6146)^2}{0.3125} \right) = 0.0944 \text{ feet}$$

$$\text{Correction}_D = K \left(\frac{1 \times 15.2084 \times (210.5946)^2}{0.25} \right) = 0.0769 \text{ feet}$$

$$\text{Correction}_E = K \left(\frac{1 \times 7.2501 \times (210.5896)^2}{0.25} \right) = 0.0366 \text{ feet}$$

$$\text{Correction}_F = K \left(\frac{1 \times 0.8835 \times (210.5746)^2}{0.25} \right) = 0.0045 \text{ feet}$$

$$\text{Correction}_G = \text{No correction}$$



Composite Construction to Illustrate:
 Riveted In-and-Out Arrangement.
 Riveted Shingled Arrangement.
 Butt-Welded Arrangement.

Note: The tank shell illustrated above may not be encountered in actual service. This example is used only to illustrate the different aspects to computations which are contained in the example calculations.

Figure B-1—Upright Cylindrical Tank, Composite Construction

United States Department of Commerce
National Institute of Standards and Technology
Gaithersburg, Maryland 20899

REPORT OF CALIBRATION

For: 100 Foot Lufkin Steel Tape

NIST No. 15557

Submitted by:

This tape was calibrated under applied tension while supported on a horizontal flat surface. The distances between the terminal points of the indicated intervals have the following lengths at 20 degrees Celsius (68 degrees Fahrenheit):

TENSION (pounds)	INTERVAL (feet)	LENGTH (feet)	UNCERTAINTY (feet)
10	0 to 50	50.0019	0.0005
10	0 to 100	100.0026	0.0010
30	0 to 100	100.0210	0.0010

The uncertainty is based on the limits imposed by the standards used for the calibration, the length of the interval, the character of the terminal points, and the behavior of the tape.

The terminal points of the indicated intervals are the centers of the graduations near the tape edge where the shortest graduations appear.

The average AE value for this tape is 109091 pounds. (AE=Average Elasticity)

The average weight per foot of this tape is 0.01296 pound.

The assumed thermal expansion of this tape is 0.00000645 FT/FT/DEG F.

The exact relationship between the international system of units and the U.S. customary units of length is one foot equals 0.3048 meter.

Tables of computed lengths and tensions for various temperatures and suspensions are attached. The tables are computed from the catenary tape equation and the tape physical constants. All support points are equally spaced along a horizontal line and the tension is horizontally applied.

Measurements were made by _____.

For the Director,

Order No. GD-024
Test No. 821/250176-92
Date: May 12, 1992

Dr. Dennis A. Swyt, Chief
Precision Engineering Division
Center for Manufacturing Engineering

Figure B-2—Typical NIST Report of Calibration

Table B-1—Typical Measurement Record of an Upright Cylindrical Steel Tank for Example Calculations

Date: 5/19/92Strapped by: WS SLTank No.: 117(Old Tank No.): N/AOwner's Name: S.R. Co.Plant or Property name: Corley TerminalLocation: Corley, IllinoisManufactured by: Braker Plate Co.Erected by: Braker Plate Co.Prepare 3 copies, 1-inch increments in gallon Fractions to noneTable Form or Size Desired: S.R. Co. Form 746, 11 by 17½ inchesA. Total Shell Height: 48'-0"B. Shell to Gauge Point: 0'-6½"C. Total A Plus B: 48'-6½"D. Total Gauge Height: 48'-6½"Horizontal Distance of Gauge Point to Tank Shell: 2'-0"Describe Gauge Point: Top lip of 8' diameter hatch, opposite hingeLocation of Overflow from Top of Shell: 2'-6"Safe Fill Height (meas.) 45'-5½" By Customer: N/AType of Roof: Cone (¾ inch, 12-inch slope) Weight of Floating Roof: 4900 pounds (See Deadwood)Tank Contents—Name: Water Avg. Liquid Temp., °F: 72Gauge: 39'-3"; Tank Service Gasoline API Gravity: 60.0 at 60°FMaster tape measurement 210.680' at 10 lbs. Tension NIST No. 15557Working Tape circumference 210.690' at 20 lbs. TensionDiff -0.01'

Shell Circumferences:

A <u>210.690'</u>	D <u>210.610'</u>	G <u>210.575'</u>
B <u>210.665'</u>	E <u>210.605'</u>	H
C <u>210.630'</u>	F <u>210.590'</u>	J

Descriptions of Shell Plates and Joints

Ring No.	Thick- ness, in.	Type of Vertical Joint	Set, In or Out	Width of Lap or Strap, in.	Thick- ness, Butt Strap, in.	No. of Sections	Inside Ring Height
(Btm. ring)							
1	¾	Butt Rivet	out	13	1.00	14	7'-11½"
2	¾	Butt Rivet	in	10	.75	14	7'-11½"
3	¾	Lap Rivet	out	2½	..	14	8'- 1½"
4	¾	Lap Rivet	in	2	..	14	7'-11½"
5	¾	Lap Weld	in	1½	..	14	7'-11½"
6	¾	Butt Weld	..	..	..	14	8'- 0½"
7	..	..	..	..	..	..	..

Deadwood Measurements (continued from Table B-1)

Description	No.	Size	Elevation	
			From	To
Bottom Angle	1	6 × 4 × ½" at 16.2 lb × 210.6'	0'-0"	0'-6"
Column Bases	1	8" Channel at 11.5 lb × 7.5'	0'-3½"	0'-11½"
Column	1	12" Channel at 20.7 lb	0'-11½"	48'-0"
Column	1	9" Channel at 13.4 lb	0'-11½"	48'-0"
Inside Butt Straps	14	17" × ½" at 28.9 lb	0'-6"	7'-11½"
Inside Butt Straps	14	15" × ½" at 19.13 lb	7'-11½"	15'-11"
Manways	2	20" Diameter × 7"	1'-6"	3'-6"
Sump	1	24" Diameter × 10"	Below 0'-0"	
Rafters	35	6" Channel at 8.2 lb	47'-6"	48'-0"

Note: Type of Bottom 3.5" Crown up at center.

Roof Type – 8" diameter aluminum pontoon floating roof, operating elevation at gauge point 3'-6" to underside of pontoon.

ft. (') = feet, No. = Number; In. (") = Inch(es); Meas. = Measurements; lbs = pounds; Diff. = Difference; Avg. Liquid Temp. = Average Liquid Temperature.

Table B-2—Summary of Circumference Corrections

Circumference	Measured Circ. ft.	Less Master Tape Corr.	Less Tape Rise	Less Liquid Head	Less Plate Thickness	Corrected Internal Circumference
A	210.690 ft.	0.0154	0.1474	0	0.2618	210.2654
B	210.665 ft.	0.0154	0.0930	0.0904	0.2291	210.2371
C	210.630 ft.	0.0154	0.0068	0.0944	0.1636	210.3498
D	210.610 ft.	0.0154	0.0048	0.0769	0.1309	210.3820
E	210.605 ft.	0.0154	0.0048	0.0366	0.1309	210.4173
F	210.590 ft.	0.0154	0.0048	0.0045	0.1309	210.4344
G	210.575 ft.	0.0154	None	None	0.1309	210.4287

Note: ft. = foot/feet; Tape Corr. = Tape Correction

B.1.5 CORRECTION OF OUTSIDE TO INSIDE CIRCUMFERENCE

$$\text{Circumference Deduction for Plate Thickness} = \frac{\pi t}{6}$$

Where:

t = Plate thickness in inches.

Ring No.	Thickness (inches)	Correction (feet)
1	0.5	0.2618
2	0.4375	0.2291
3	0.3125	0.1636
4	0.25	0.1309
5	0.25	0.1309
6	0.25	0.1309

B.1.6 ADDITIONAL OF LIQUID HEAD STRESS TO INTERNAL CIRCUMFERENCES

The same formula used in B.1.4 can be used to calculate the expansion of the tank shell. This computation expands the tank shell based upon the density of product to be stored in the tank. This correction is used to determine an average stressed inside diameter of the tank. By using the stressed inside diameter of the tank, the expansion and contraction of the tank shell due to liquid head is more representative for volume computations.

$$\text{Correction} = K \frac{GhC^2}{t}$$

Where:

G = specific gravity at 60°F of the liquid to be stored in the tank
(0.7389 in the example).

Correction_A = no correction.

$$\text{Correction}_B = K \left(\frac{0.7389 \times 7.9583 (210.2371)^2}{0.4375} \right) = 0.0169 \text{ feet}$$

$$\text{Correction}_C = K \left(\frac{0.7389 \times 8.125 \times (210.3498)^2}{0.3125} \right) = 0.0242 \text{ feet}$$

$$\text{Correction}_D = K \left(\frac{0.7389 \times 7.9583 \times (210.3820)^2}{0.25} \right) = 0.0297 \text{ feet}$$

$$\text{Correction}_E = K \left(\frac{0.7389 \times 1.0 \times (210.4173)^2}{0.25} \right) = 0.0037 \text{ feet}$$

$$\text{Correction}_F = K \left(\frac{0.7389 \times 1.5917 \times (210.4344)^2}{0.25} \right) = 0.0059 \text{ feet}$$

$$\text{Correction}_G = K \left(\frac{0.7389 \times 1.6084 \times (210.4287)^2}{0.25} \right) = 0.0060 \text{ feet}$$

Internal Circumference B, ring full stressed = 210.2371 + 0.0169 = 210.2540 feet

Internal Circumference C, ring full stressed = 210.3498 + 0.0242 = 210.3740 feet

Internal Circumference D, ring full stressed = 210.3820 + 0.0297 = 210.4117 feet

Internal Circumference E, ring full stressed = 210.4173 + 0.0037 = 210.4210 feet

Internal Circumference F, ring full stressed = 210.4344 + 0.0059 = 210.4405 feet

Internal Circumference G, ring full stressed = 210.4287 + 0.0060 = 210.4347 feet

B.1.7 INCREMENTAL VOLUME CALCULATION

The following calculations determine the inch incremental volume for each ring when it is just full of oil, in this case, 60.0 API gravity, 0.7389 specific gravity (see Figure B-1).

Ring No. 1

Internal Circumference A	:	210.2654
Internal Circumference B plus 0.2291 plate thickness	:	<u>210.4662</u>
		420.7316

$$\text{Full stressed circumference} = \frac{420.7316}{2} = 210.3658 \text{ feet}$$

$$\text{Internal radius} = \frac{210.3658}{2\pi} \cdot 12 = 401.7691 \text{ inches}$$

$$\text{Incremental volume} = \pi(401.7691)^2 \div 9702 = 52.2687 \text{ bbls per inch}$$

Ring No. 2

$$\text{Internal Circumference B, ring full stressed} : 210.2540$$

$$\text{Internal Circumference C minus 0.2291} : \underline{210.1207}$$

$$\text{plate thickness} 420.3747$$

$$\text{Full stressed circumference} = \frac{420.3747}{2} = 210.1874 \text{ feet}$$

$$\text{Internal radius} = \frac{210.1874}{2\pi} \cdot 12 = 401.4284 \text{ inches}$$

$$\text{Incremental volume} = \pi(401.4284)^2 \div 9702 = 52.1801 \text{ bbls per inch}$$

Ring No. 3

$$\text{Internal Circumference C, ring full stressed} : 210.3740$$

$$\text{Internal Circumference D plus 0.1309 plate thickness} : \underline{210.5426}$$

$$420.9166$$

$$\text{Full stressed circumference} = \frac{420.9166}{2} = 210.4583 \text{ feet}$$

$$\text{Internal radius} = \frac{210.4583}{2\pi} \cdot 12 = 401.9457 \text{ inches}$$

$$\text{Incremental volume} = \pi(401.9457)^2 \div 9702 = 52.3147 \text{ bbls per inch}$$

Ring No. 4

$$\text{Internal Circumference D, ring full stressed} : 210.4117$$

$$\text{Internal Circumference E, ring full stressed} : \underline{210.4210}$$

$$420.8327$$

$$\text{Full stressed circumference} = \frac{420.8327}{2} = 210.4164 \text{ feet}$$

$$\text{Internal radius} = \frac{210.4164}{2\pi} \cdot 12 = 401.8657 \text{ inches}$$

$$\text{Incremental volume} = \pi(401.8657)^2 \div 9702 = 52.2938 \text{ bbls per inch}$$

Ring No. 5

$$\text{Internal Circumference F, ring full stressed} : 210.4405 \text{ feet}$$

$$\text{Internal radius} = \frac{210.4405}{2\pi} \cdot 12 = 401.9117 \text{ inches}$$

$$\text{Incremental volume} = \pi(401.9117)^2 \div 9702 = 52.3058 \text{ bbls per inch}$$

Ring No. 6

$$\text{Internal Circumference G, ring full stressed} : 210.4347 \text{ feet}$$

$$\text{Internal radius} = \frac{210.4347}{2\pi} \cdot 12 = 401.9007 \text{ inches}$$

$$\text{Incremental volume} = \pi(401.9007)^2 \div 9702 = 52.3029 \text{ bbls per inch}$$

B.1.8 VOLUMETRIC INCREASE FOR EACH RING, FOR EACH INCH OF LIQUID HEAD ABOVE THE RING.

$$\text{Volumetric Increase } (\Delta V) = \frac{\pi W G d^3 h}{4 E t}$$

Where:

- W = 62.3 lbs / cubic foot.
- G = 0.7389 specific gravity, at 60°F, of liquid to be stored in the tank.
- d = 66.9673 feet average inside diameter (from ring full stressed circumference).
- h = ring height in inches.
- t = plate thickness in inches.
- E = modulus of elasticity of steel (29,000,000 PSI).

$$\text{Let } K = \frac{\pi W G d^3}{4 E} ; \text{ then } K = 0.3744156 \text{ and } \Delta V = K \frac{h}{t}$$

$$\text{Ring No. 1 : } \Delta V = \frac{95.5}{0.50} \times \frac{0.3744156}{9702} = +0.0074 \text{ barrels per inch}$$

$$\text{Ring No. 2 : } \Delta V = \frac{95.5}{0.4375} \times \frac{0.3744156}{9702} = +0.0084 \text{ barrels per inch}$$

$$\text{Ring No. 3 : } \Delta V = \frac{97.5}{0.3125} \times \frac{0.3744156}{9702} = +0.0120 \text{ barrels per inch}$$

$$\text{Ring No. 4 : } \Delta V = \frac{95.5}{0.25} \times \frac{0.3744156}{9702} = +0.0147 \text{ barrels per inch}$$

$$\text{Ring No. 5 : } \Delta V = \frac{95.5}{0.25} \times \frac{0.3744156}{9702} = +0.0147 \text{ barrels per inch}$$

$$\text{Ring No. 6 : } \Delta V = \text{None}$$

Incremental Correction:

$$\text{Ring No. 1 : None}$$

$$\text{Ring No. 2 : } 0.0074 = 0.0074 \text{ barrels per inch}$$

$$\text{Ring No. 3 : } 0.0074 + 0.0084 = 0.0158 \text{ barrels per inch}$$

$$\text{Ring No. 4 : } 0.0074 + 0.0084 + 0.0120 = 0.0278 \text{ barrels per inch}$$

$$\text{Ring No. 5 : } 0.0074 + 0.0084 + 0.0120 + 0.0147 = 0.0425 \text{ barrels per inch}$$

$$\text{Ring No. 6 : } 0.0074 + 0.0084 + 0.0120 + 0.0147 + 0.0147 = 0.0572 \text{ barrels per inch}$$

B.2 Computation of Capacity Table Height

- A) Shell Height 48'-0"
 - B) Shell to Gauge Point 0'-6½"
 - C) A plus B 48'-6½"
 - D) Reference Gauge Height 48'-6½"
- Difference ¼" up at Strike Point

Shell Height	48'-0"
Less Difference	0'-0¼"
Less Overflow Distance	2'-6"
Effective Capacity Table Height	45'-5¼"

B.3 Deadwood Computations

B.3.1 STRUCTURAL DEADWOOD

From	To	Description	Computations	Deduction in Barrels per Inch
0' - 0"	0' - 6"	Bottom Angle	$210.6 \times 12 \times 4.75 \div 9702 \div 6$	-0.2062
0' - 3½"	0' - 11½"	Column Base	$7.5 \times 12 \times 3.36 \div 9702 \div 8$	-0.0039
0' - 11½"	46' - 0"	Center Column	$(6.03 + 3.89) \div 9702$	-0.0010
0' - 6"	7' - 11½"	Butt Straps	$14 \times 17 \times 0.5 \div 9702$	-0.0123
7' - 11½"	15' - 11"	Butt Straps	$14 \times 15 \times 0.375 \div 9702$	-0.0081
1'6" - 6"	3' - 6"	Manways	$20^2 \times 0.7854 \times 7 \times 2 \div 9702 \div 20$	+0.0227
Below	0' - 0"	Sump	$24^2 \times 0.7854 \times 10 \div 9702$	+0.4663
47' - 6"	48' - 0"	Rafters	None due to overflow	...

Note: " = inch(es); ' = foot/feet.

B.3.2 BOTTOM COMPUTATIONS (3½ INCH CROWNUP BOTTOM)

Bottom Ring, barrels per inch = 52.2683

Note: ¼ inch up at Strike Point. Difference to be considered in Capacity Table heights.

$52.2683 \times 3.5/3 = 60.9797$ bbls. $\div (3.5)^3 = 1.4222671$ spread factor

Tank Heights From	To	(Diff in Spread Heights) Multipliers	Spread Factor $\times$ Multiplier Barrels per Increment
0'-0"	0'-0¼"	$3.5^3 - 3.25^3 = 8.546875$	- 12.1559
0'-0¼"	0'-1¼"	$3.25^3 - 2.25^3 = 22.9375$	- 32.6233
0'-1¼"	0'-2¼"	$2.25^3 - 1.25^3 = 9.4375$	- 13.4226
0'-2¼"	0'-3¼"	$1.25^3 - .25^3 = 1.9375$	- 2.7556
0'-3¼"	0'-3½"	$.25^3 = 0.015625$	- 0.0223
			60.9797 barrels

Note: " = inch(es).

B.3.3 ROOF COMPUTATION

Data = 8 inches diameter pontoon, Aluminum Internal Floating Roof Weight = 4,900 pounds

Compute at 60.0 API, pounds per gallon = 6.151

Due to the roof design, the roof shall float in one half (1/2) of the pontoon diameter.

Displacement

$4,900 \text{ lbs} \div 6.151 \text{ lbs/gal} \div 42 = 18.9671$ barrels

Spread

$18.9671 \text{ bbls} \div (4)^2 = 1.1854438$ spread factor

Tank Heights From	To	(Diff in Spread Hts) Multipliers	Spread Factor $\times$ Multiplier Barrels per Increment
3'-6¼"	3'-7¼"	$1^2 = 1$	- 1.1854
3'-7¼"	3'-8¼"	$2^2 - 1^2 = 3$	- 3.5563
3'-8¼"	3'-9¼"	$3^2 - 2^2 = 5$	- 5.9272
3'-9¼"	3'-10¼"	$4^2 - 3^2 = 7$	- 8.2982
			18.9671 barrels

Note: ' = foot/feet; " = inch(es); Bbls = barrels.

B.3.4 DEADWOOD RECAPITULATION

Note that the following heights are computed to allow for the difference in elevation at the strike point in the tank vs. the intersection of the tank shell and bottom.

Table Height		Structural	Bottom	Roof	Total Deadwood
From	To	Deadwood	Bbls per Inch	Bbls per Inch	Bbls per Inch
	0'-0"	+0.4147	-12.1559	..	-11.7412
0'-0"	0'-1"	-0.2062	-32.6233	..	-32.8295
0'-1"	0'-2"	-0.2062	-13.4226	..	-13.6288
0'-2"	0'-3"	-0.2066	-2.7556	..	-2.9622
0'-3"	0'-4"	-0.2087	-0.0223	..	-0.2310
0'-4"	0'-5"	-0.2101	..	..	-0.2101
0'-5"	0'-6"	-0.1616	..	..	-0.1616
0'-6"	0'-10"	-0.0162	..	..	-0.0162
0'-10"	0'-11"	-0.0158	..	..	-0.0158
0'-11"	1'-0"	-0.0144	..	..	-0.0144
1'-0"	1'-5"	-0.0133	..	..	-0.0133
1'-5"	1'-6"	-0.0076	..	..	-0.0076
1'-6"	3'-5"	+0.0094	..	..	+0.0094
3'-5"	3'-6"	+0.0037	..	..	+0.0037
3'-6"	3'-7"	-0.0133	..	-1.1854	-1.1987
3'-7"	3'-8"	-0.0133	..	-3.5563	-3.5696
3'-8"	3'-9"	-0.0133	..	-5.9272	-5.9405
3'-9"	3'-10"	-0.0133	..	-8.2982	-8.3115
3'-10"	7'-10"	-0.0133	..	..	-0.0133
7'-10"	7'-11"	-0.0128	..	..	-0.0128
7'-11"	8'-0"	-0.0107	..	..	-0.0107
8'-0"	15'-10"	-0.0091	..	..	-0.0091
15'-10"	15'-11"	-0.0070	..	..	-0.0070
15'-11"	24'-0"	-0.0010	..	..	-0.0010
24'-0"	24'-1'	-0.0010	..	..	-0.0010
24'-1"	31'-11"	-0.0010	..	..	-0.0010
31'-11"	32'-0"	-0.0010	..	..	-0.0010
32'-0"	39'-11"	-0.0010	..	..	-0.0010
39'-0"	40'-0"	-0.0010	..	..	-0.0010
40'-0"	45'-5"	-0.0010	..	..	-0.0010
45'-5"	45'-5 1/4"	-0.0008	..	..	-0.0008

Note: ' = foot/feet; " = inch(es); Bbls = barrels.

Table B-3A—Tank Table Run Sheet

From	To	No. Inc.	Incremental Bbls per inch	Liquid Head Correction Bbl per inch	Deadwood Deduction	Net Bbls per inch	Accumulated Barrels
	0'- 0"	..	13.0672	0	-11.7412	1.3260	1.3260
0'- 0"	0'- 1"	1	52.2687	0	-32.8295	19.4392	20.7652
0'- 1"	0'- 2"	1	..	0	-13.6288	38.6399	59.4051
0'- 2"	0'- 3"	1	..	0	-2.9622	49.3065	108.7116
0'- 3"	0'- 4"	1	..	0	-0.2310	52.0377	160.7493
0'- 4"	0'- 5"	1	..	0	-0.2101	52.0586	212.8079
0'- 5"	0'- 6"	1	..	0	-0.1616	52.1071	264.9150
0'- 6"	0'-10"	4	..	0	-0.0162	52.2525	473.9250
0'-10"	0'-11"	1	..	0	-0.0158	52.2529	526.1779
0'-11"	1'- 0"	1	..	0	-0.0144	52.2543	578.4322
1'- 0"	1'- 5"	5	..	0	-0.0133	52.2554	839.7092
1'- 5"	1'- 6"	1	..	0	-0.0076	52.2611	891.9703
1'- 6"	3'- 5"	23	..	0	+0.0094	52.2781	2094.3666
3'- 5"	3'- 6"	1	..	0	+0.0037	51.2724	2146.6390
3'- 6"	3'- 7"	1	..	0	-1.1987	51.0700	2196.7090
3'- 7"	3'- 8"	1	..	0	-3.5696	48.6991	2246.4081
3'- 8"	3'- 9"	1	..	0	-5.9405	46.3282	2292.7363
3'- 9"	3'-10"	1	..	0	-8.3115	43.9572	2336.6935
3'-10"	7'-10"	48	..	0	-0.0133	52.2554	4844.9527
7'-10"	7'-11"	1	..	0	-0.0128	52.2559	4897.2086
7'-11"	8'- 0"	1	52.2023	0.0056	-0.0107	52.1972	4949.4058
8'- 0"	15'-10"	94	52.1801	0.0074	-0.0091	52.1784	9854.1754
15'-10"	15'-11"	1	52.2811	0.0137	-0.0070	52.2878	9906.4632
15'-11"	24'- 0"	97	52.3147	0.0158	-0.0010	52.3295	14982.4247
24'- 0"	24'- 1"	1	52.2990	0.0248	-0.0010	52.3228	15034.7475
24'- 1"	31'-11"	94	52.2938	0.0278	-0.0010	52.3206	19952.8839
31'-11"	32'- 0"	1	52.3028	0.0388	-0.0010	52.3406	20005.2245
32'- 0"	39'-11"	95	52.3058	0.0425	-0.0010	52.3473	24978.2180
39'-11"	40'- 0"	1	52.3036	0.0535	-0.0010	52.3561	25030.5741
40'- 0"	45'- 5"	65	52.3029	0.0572	-0.0010	52.3591	28433.9156
45'- 5"	45'-5½"	1	39.2272	0.0429	-0.0008	39.2693	28473.1849

Note: Bbls = Barrels; " = inch(es); ' = foot/feet.

Table B-3B—Run Sheet for Soft Conversion to Metric

The following runsheet is a soft conversion of the previous example runsheet. The previous volumes have been multiplied by a factor which converts barrels at 60°F to cubic meters at 15°F.

The factor is as follows:

Volume conversion: 9702 cubic inches per barrel
61023.744095 cubic inches per cubic meter
equals 0.158973

Temperature conversion: 15°C = 59°F (refer to Appendix D)

$$K = 1 + \left[(12.4 \times 10^{-6} \times \Delta T_s) + (4.0 \times 10^{-9} \times \Delta T_s^2) \right]$$

$$\Delta T_s = \text{steel temperature minus } 60^\circ\text{F}$$

$$\Delta T_s = 59 - 60 = -1$$

$$K = 1 + [(0.0000124 \times -1) + (0.000000004 \times (-1 \times -1))]$$

$$K = 0.9999876$$

Both factors multiplied together = $0.1589873 \times 0.9999876$
= 0.1589853

The following example shows how runsheets are normally presented.

Line No.	Gauge	No.	Cubic Meters Factor	Total
0	00-00-0/0			0.210815
1	0 -1-0/0	1	3.090547	3.301362
2	0 -2-0/0	1	6.143177	9.444539
3	0 -3-0/0	1	7.839010	17.283549
4	0 -4-0/0	1	8.273230	25.556779
5	0 -5-0/0	1	8.276554	33.833333
6	0 -6-0/0	1	8.284264	42.117597
7	0-10-0/0	4	8.307381	75.347121
8	0-11-0/0	1	8.307442	83.654563
9	1 -0-0/0	1	8.307667	91.962230
10	1 -5-0/0	5	8.307842	133.501440
11	1 -6-0/0	1	8.308746	141.810186
12	3 -5-0/0	23	8.311451	332.973559
13	3 -6-0/0	1	8.310536	341.284095
14	3 -7-0/0	1	8.119380	349.403475
15	3 -8-0/0	1	7.742442	357.145917
16	3 -9-0/0	1	7.365504	364.511421
17	3-10-0/0	1	6.988550	371.499971
18	7-10-0/0	48	8.307842	770.276387
19	7-11-0/0	1	8.307904	778.584291
20	8 -0-0/0	1	8.298589	786.882880
21	15-10-0/0	94	8.295600	1566.669280
22	15-11-0/0	1	8.312972	1574.982252
23	24 -0-0/0	97	8.319622	2381.985586
24	24 -1-0/0	1	8.318601	2390.304187
25	31-11-0/0	94	8.318207	3172.215645
26	32 0-0/0	1	8.321433	3180.537078
27	39-11-0/0	95	8.322452	3971.170018
28	40 -0-0/0	1	8.323889	3979.493907
29	45 -5-0/0	65	8.324328	4520.575227
30	45 -5-3/4	1	6.243270	4526.818497

Note: No. = number.

APPENDIX C—GUIDELINES FOR COMPUTER INPUT

C.1 Introduction

C.1.1 Throughout the industry, many companies are installing tank capacity tables into their computer systems. Inventory programs and many other systems require the input of capacity tables in order to determine quantities in their facilities. In order to precisely duplicate the existing capacity tables into computer systems, the increment factors must be utilized to insure accurate quantities at measured liquid levels.

C.1.2 Exact replication of capacity tables in computer systems is required for custody transfer transactions. *Increment factors* are data used to exactly generate the capacity tables in a condensed form. Increment factors are commonly referred to as *runsheets*, *critical points*, or *skeleton table*. (Refer to Appendix B, Tables B-3A and B-3B.)

C.1.3 The increment factors on floppy disk should be requested from the contractor at the time of tank calibration. This data is normally available in an ASCII format utilizing MS DOS operating system.

C.2 Criteria

C.2.1 INCREMENTAL VOLUME CONSIDERATIONS

When capacity tables are being prepared, the unit volume and the incremental height must be taken into consideration. The unit volume is commonly barrels, gallons, cubic meters, liters, and cubic feet. The incremental height is the difference between levels of capacity in the capacity table. The incremental heights can be 1 inch, $\frac{1}{2}$ inch, $\frac{3}{4}$ inch, $\frac{5}{8}$ inch, 0.1 foot, 0.01 foot, 1 centimeter or 1 millimeter. The most common volumes and incremental heights expressed in capacity tables are barrels per one-inch and cubic meters per 1 centimeter with average fractional values to $\frac{1}{8}$ inch and 1 millimeter respectively.

C.2.2 FRACTIONS

Fractional values should not be displayed on capacity tables because the fractional values are an average value. When fractional values are used, the quantities will not match the exact volumes generated by a computer program. By interpolation between incremental volumes, the volumes are more precise, and manual interpolation will match the computer generated volumes.

C.2.3 INCREMENTAL FACTOR DEVELOPMENT

Incremental factors basically are two items, Cylindrical Volumes and Deadwood Displacement.

C.2.3.1 *Cylindrical Volumes* are the final corrected volumes per increment of each ring or course of which the tank is constructed. If a tank has six rings, then there are six separate volumes per increment for each level of height. If the tank has six eight feet (8 feet-0 inch) high rings, then a different volume per increment will be shown from 0 feet to 8 feet, 8 feet to 16 feet, 16 feet to 32 feet, etc. For an example see Appendix B.

C.2.3.2 *Deadwood* is defined as any appurtenance that adds or deducts volume by its dimensions. The tank bottom, floating roof, sumps, roof supports, internal piping affects the total tank capacity. These appurtenances are deducted from the cylindrical volume in relation to the measured elevation above or below the strike point or zero elevation on the incremental factor sheet.

C.2.3.3 The length of the incremental factor sheet is dependent upon the amount of differing elevations that deadwood is distributed inside the tank. Most deadwood is located in the bottom ring or course of a tank. Incremental factors will have many lines of differing volumes from zero elevation to the top of the bottom ring or course. Above the bottom ring, there will be only the incremental volumes (less deadwood) of the successive rings or courses of the tank.

C.2.3.4 If fewer data lines of the capacity table's incremental factors are utilized in a computer system, then the replication accuracy of the capacity table is distorted. If random points on a capacity are entered as the incremental factors for a computer system, then levels between these points will not match the capacity table and can not be used for custody transfer transactions.

C.2.4 REPLICATION ACCURACY

C.2.4.1 Exact replication of capacity tables is required for all custody transfer transactions. Whenever possible it is recommended that unit volumes on capacity tables be expressed in whole numbers (integer) for ease of replication accuracy.

C.2.4.2 When volumes are expressed to three decimal places or less (for example, 2233.455 cubic meters or 14048.01 barrels), software programming must take into account the truncation and rounding process. In situations where capacity tables are computed in barrels to two decimals and expressed in one-inch increments, the replication accuracy will be to within 0.02 barrels at any given level throughout a tank. It is not mathematically possible to generate a more precise replication of volume when the certified capacity table is printed in one-inch increments with volumes to two decimal places and incremental factors used

in the computer system are in $\frac{1}{8}$ inch increments and seven significant digits.

C.2.5 SOFTWARE CONSIDERATIONS

The development of a computer program for determining precise tank capacities must be based upon the computations detailed in Chapter 2.2A. Special attention must be paid to the following items:

- a. Actual incremental factors must be utilized for generating capacities.
- b. Appropriate rounding/truncation procedures must be utilized.
- c. Floating roof at rest elevation and critical zone must be defined.
- d. API gravity used to compute the capacity table must be known in order to compute the roof correction factor for differing gravities at observed temperatures.
- e. Shell temperature correction factors are important for increased accuracy of inventory (see Appendix E).
- f. Volume correction factors 5B and 6B are needed for correction of product to 60°F from observed temperature.

C.3 Verification

For custody transactions, the incremental factor accuracy must be confirmed. It is recommended that levels on the capacity table and computer system be checked for replication at five to six levels in the lower 8 feet 0 inches of the capacity table and at five to six random levels throughout the balance of the capacity table.

C.4 Conclusion

C.4.1 The guidelines presented herein will enable accurate replication of gauge tables for custody transfer transactions using modern computer systems. These systems provide the means for efficient management of tank capacity tables used in custody transfer transactions and inventory control.

C.4.2 It must be realized, however, that the use of computer systems by itself will not ensure the integrity of the capacity table, but is dependent upon the primary data source. It is important to ensure that the primary data source, tank capacity tables are in accordance with the latest MPMS standards to obtain the maximum accuracy possible with a computer inventory system.

APPENDIX D— SHELL TEMPERATURE CORRECTION FACTORS

D.1 Shell Temperature Determination

D.1.1 API Standard 2550 *Method for Measurement and Calibration of Upright Cylindrical Tanks*, introduced first in 1965, establishes the following equation to determine shell temperature (T_s) for uninsulated tanks:

$$T_s = \frac{K \times T_L + T_a}{K + 1} \quad (\text{D-1})$$

Where:

- K = 1 (assumes equal weightage for liquid and ambient temperatures).
- T_L = liquid temperature of liquid within the tank.
- T_a = ambient temperature.

D.1.2 Subsequent investigations have concluded that shell temperature is more dependent on the product temperature and proportionately less influenced by ambient temperature.

D.1.3 The shell temperature may be expressed by the following equation:

$$T_s = \frac{K \times T_L + T_a}{K + 1}$$

Where:

- $K = \frac{1}{K_1}$
- $K_1 = \left\{ \left[4 \times (T_L - 150) \right] + \left[16.5 \times v \times \mu^{0.5} \right] + \left[340 \times \mu^{0.32} \right] + (250 - D) \right\} \times 10^{-4}$
- μ = viscosity: $1 < \mu < 1000$ cp.
- V = wind velocity: $0 < V < 30$ mph.
- T_L = liquid temperature: $T_L < 150^\circ\text{F}$.
- T_s = shell temperature: $^\circ\text{F}$.
- T_a = ambient temperature: $^\circ\text{F}$.

D.1.4 Value of K may vary from a minimum of 2.5 to 30 and higher depending on extreme conditions (of viscosity and wind velocity).

D.1.5 For most observations, the K value lies in between five and ten.

D.1.6 Assuming an average value of 7 for K , the shell temperature equation may be simplified as follows:

$$T_s = \frac{(7 \times T_L) + T_a}{7 + 1} \quad (\text{D-2})$$

$$T_s = \frac{(7 \times T_L) + T_a}{8}$$

D.1.7 This simplified equation gives a weightage of approximately 88 percent for liquid temperature and 12 percent for ambient temperature.

D.1.8 Assuming a value of K of 7 can, however, introduce a minor bias in the determination of shell temperature for extreme cases. Nevertheless, a value of seven is still estimated to yield a more realistic shell temperature than the value of one used in Equation D-1. The data used for the development of simplified new Equation D-2 is limited but considered accurate.

D.1.9 Additional data would be welcome in the interest of improving accuracy of the equation and its application. It may then be possible to develop better average K factors for various product groupings.

^{D-1} Based on the publication *Correlation Predicts Tank Shell Temperature*, by S. Sivaraman et al, *Oil and Gas Journal*, October 3, 1988.

D.2 Shell Temperature Correction Factors (VCF) for Expansion and Contraction of Upright Cylindrical Steel Tanks Due to Temperature

D.2.1 Tanks undergo expansion or contraction due to variations in ambient and product temperatures. Such expansion or contraction in tank volume may be computed once the tank shell temperature is determined.

D.2.2 For tanks that are insulated, the tank shell temperature (T_s) is assumed to be the same as the temperature of the product (T_L) stored within the tank (i.e.: $T_s = T_L$). For tanks that are not insulated, the shell temperature is a weighted average of the ambient and the product temperature based upon Equation D-3.

D.2.3 Once the shell temperature is determined, the shell temperature correction factor (Kc) is computed using Equation D-4.

$$T_s = \frac{(7 \times T_L) + T_a}{8} \quad (D-3)$$

$$Kc = 1 + (12.4 \times 10^{-6} \Delta T_s) + (4.0 \times 10^{-9} \Delta T_s^2) \quad (D-4)$$

Where:

T_L = liquid temperature.

T_a = ambient temperature.

T_s = shell temperature.

ΔT_s = shell temperature minus 60 degrees Fahrenheit (60°F).

D.3 Application of Shell Temperature Correction

Case 1: Capacity Table at Standard Temperature of 60°F

- Volume at a given level at 60°F = 100,000 bbls
- Ambient Temperature = 70°F
- Product Temperature = 300°F
- Compute capacity table volume reflecting above conditions

Solution:

- a. Calculate Shell Temperature T_s at 300°F product Temperature:

$$T_s = \frac{(7 \times T_L) + T_a}{8} \quad (D-5)$$

$$T_s = \frac{7 \times 300 + 70}{8}$$

$$T_s = \frac{2170}{8} = 271.25^\circ\text{F}$$

- b. Compute the Shell Temperature Correction factor at 271.25°F:

$$Kc = 1 + (12.4 \times 10^{-6} \times \Delta T_s) + (4.0 \times 10^{-9} \times \Delta T_s^2)$$

$$\Delta T_s = (T_s - 60)^\circ\text{F}$$

$$\Delta T_s = (271.25 - 60)^\circ\text{F}$$

$$\Delta T_s = 211.25^\circ\text{F}$$

$$Kc = 1 + (12.4 \times 10^{-6} \times 211.25) + (4.0 \times 10^{-9} \times \Delta T_s^2)$$

$$Kc = 1.00279801$$

- c. Compute the Corrected Volume:

$$V = \text{Volume at } 60^\circ\text{F} \times \text{Shell Temperature Correction Factor (Kc)}$$

$$V = 100,000 \text{ Bbl} \times 1.00279801$$

$$V = 100,279.80 \text{ Bbl.}$$

Case 2: Capacity Table Already Corrected for a Product Temperature of 300°F

When converting an existing capacity table which reflects expansion of the tank shell due to an operating temperature which differs from the observed temperature, use the following procedure:

- Volume at Given Level at 300°F = 100279.8 bbls
- Ambient Temperature = 70°F
- Temperature Capacity Table Computed at = 300°F
- Compute Capacity at a Product Temperature of 200°F

Solution:**a. Compute Shell Temperature at 300°F:**

$$T_s = \frac{7 \times 300 + 70}{8}$$

$$T_s = 271.25^\circ\text{F}$$

b. Compute Shell Temperature Correction Factor at K_c 300°F:

$$K_c = 1 + (12.4 \times 10^{-6} \times \Delta T_s) + (4.0 \times 10^{-9} \times \Delta T_s^2)$$

$$\Delta T_s = (271.25 - 60)^\circ\text{F} = 211.25^\circ\text{F}$$

$$K_c = 1 + (12.4 \times 10^{-6} \times 211.25) + (4.0 \times 10^{-9} \times 211.25^2)$$

$$K_c = 1.00279801$$

c. Correct Tank Volume To Standard Temperature of 60°F:

$$V_{60^\circ\text{F}} = \frac{100,279.80}{1.00279801} = 100,000.00 \text{ bbls}$$

d. Compute New Shell Temperature Correction Factor at 200°F:

$$T_s = \frac{7 \times 200 + 70}{8}$$

$$T_s = 183.75^\circ\text{F}$$

$$\Delta T_s = (T_s - 60)^\circ\text{F} = 183.75 - 60 = 123.75^\circ\text{F}$$

$$\text{New } K_c = 1 + (12.4 \times 10^{-6} \times 123.75) + (4.0 \times 10^{-9} \times 123.75^2)$$

$$\text{New } K_c = 1.00159576 \text{ at } 200^\circ\text{F}$$

e. Compute New Capacity Table Volume at 200°F:

$$V_{\text{new}} = 100,000.00 \text{ bbls} \times 1.0015976$$

$$V_{\text{new}} = 100,159.58 \text{ bbls}$$

Note: Shell temperature correction must not be confused with volume correction factor corresponding to product temperature. In the above example one must still apply the volume correction factor corresponding to the observed product temperature of 200 or 300°F, as the case may be, to compute volume of product contained within the tank at 60°F.

APPENDIX E—UNDERGROUND TANKS

E.1 Conditions and Procedures for Remeasurement

Underground storage tanks may be constructed of steel, concrete, or other materials; they may constitute horizontal or vertical cylinders with flat or dished ends, rectangular or irregularly shaped prisms with flat surfaces, or other solids bounded by a combination of flat or curved surfaces. In large underground tanks, more deadwood may be present than in above-ground tanks of comparable size and shape. It is, therefore, important that deadwood be carefully measured. The following procedures may be used in determining the data necessary for the preparation of capacity tables for vertical underground tanks.

E.1.1 LIQUID CALIBRATION

Probably the most satisfactory method of calibrating underground tanks (initially and later) is by liquid calibration, as described in API Standard 2555 (ASTM D 1406).

E.1.2 CALIBRATION BASED ON OUTSIDE MEASUREMENTS

Calibration of underground tanks may be completed by following the procedures for outside measurements specified in this standard for aboveground tanks for the same type if the method of construction makes this possible. It must be recognized that the placing of earth backfill may result in tank deformations which might appreciably affect the tank capacity.

E.1.3 CALIBRATION BASED ON INSIDE MEASUREMENTS

Calibration of underground tanks may be based on inside measurements. The internal measurement procedure, as applied to cylindrical or rectangular tanks, should be carried out by measuring internal diameters or other dimensions for later preparation of a capacity table. This involves measurement of the following:

- a. An adequate number of diameters or other dimensions (see note) with their approximate position in the tank.
- b. The volume and location of deadwood, that is, of any fitting or other object which adds to or subtracts from the space available for liquid.

Note: When drawings for the tank are available, the diameters and other measurements should be compared with those obtained from the drawings, and any measurements which show substantial discrepancies on this comparison should be verified. A similar process of check should be employed in all cases in which reliable information beyond the measurements taken is available.

E.2 Diameter Measurements for Upright Cylindrical Steel Underground Tanks

E.2.1 Diameters should be measured after the tank has been filled at least once with liquid at least as dense as the tank is expected to contain. The usual hydrostatic test, if made, will meet this requirement.

E.2.2 Diameters should be measured with steel tapes which meet the requirements of 2.2A.6. Diameter measurements should be taken, as shown in Figure E-1, between diametrically opposite points so that the measured lines pass through a common center point, and at the same elevations at which circumferences are to be measured for aboveground tanks of corresponding type. At each such elevation, the following should be done:

- a. A minimum of $D/8$, but not less than four diameters at each elevation should be measured at approximately equal intervals around the tank, where D is the tank diameter expressed in feet.
- b. Diameters should be measured not closer than 12 inches to a vertical joint.

E.2.3 If for any reason it is impractical to take measurements at the positions described, then the diameter should be measured from a point as close to the described position as practicable, but not nearer to the horizontal or vertical joints. The reason for the deviation should be recorded in the field notes.

E.2.4 Measurements should be taken with the end of the steel tape attached to a dynamometer, one operator placing the dynamometer on the predetermined point and the second operator placing a rule end on a point diametrically opposite. The tape should be pulled along the rule until the tension for which the tape has been calibrated is registered on the dynamometer.

E.2.5 This tension (see E.2.4) should be not less than 10 pounds. A firm grip should be maintained on the rule and tape to prevent any alteration in their relative positions; the tension should be released; and a reading should be taken on the tape at that end of the rule which was against the side of the tank. The operation should be repeated at the various positions at which measurements are required throughout the tank. The measurements should be recorded clearly in white chalk on the steel plates in such a manner as to indicate the positions at which they were taken. An alternative procedure is given in E.2.9.

E.2.6 The check measurements of diameters multiplied by 3.1416 should not differ by more than the values given in Table 4.

E.2.7 Corrections for the effect of sag should be applied to the average diameter for each course using the following formula:

$$\text{Correction, in feet} = \frac{W^2 S^3}{24 P^2} \quad (\text{E-1})$$

Where:

- P = pull on tape, in pounds.
 S = span of tape, in feet.
 W = weight of tape, in pounds per foot.





Figure E-1—Locations of Measurements on Upright Cylindrical Concrete Underground Tanks

E.2.8 Corrections for the effect of stretch are unnecessary because the tension applied is that at which the tape was standardized. Corrections for the length of the dynamometer when registering this pull should be made to the average diameter of each course. The dynamometer length at this pull should be measured accurately before it is put into use

and subsequently checked before and after the calibration of each tank, the final check being made before leaving the tank site.

E.2.9 As an alternative to the procedure previously outlined, measurements may be made by in the following manner:



Measurements Shown in Plan Should be Made at Each Elevation




Figure E-2—Locations of Measurements on Rectangular Steel or Concrete Underground Tanks

- a. Establishing plumb lines a few inches distant from the tank wall at the proper locations.
- b. Measuring the distance between the plumb lines with the tape resting on the tank floor, thus eliminating the need for a sag correction.
- c. Measuring with a rule the distances from the plumb lines to the adjacent tank walls at the required elevations.
- d. Adding the two corresponding short-end measurements to the single center floor measurement to determine the required dimension for each elevation.

E.2.10 If a center column makes impractical a direct measurement of the distance between plumb lines, a circular template may be cut and fitted around the base of the column with points on the circumference of this circle marked to correspond with the radial lines on which diameters are to be measured. The total diameter may then be found, equal to the diameter of the template plus the two short-end measurements plus two radial measurements between the circumference of the template and the plumb lines adjacent to the shell.

E.3 Diameter Measurements for Upright Cylindrical Concrete Underground Tanks

- a. Diameters should be measured at the following elevations as shown in Figure E-2:
 1. 1 foot above the tank bottom.
 2. 1 foot below the tank roof.
 3. At intermediate elevations not more than 6 feet apart, unless it can be shown that the walls are vertical, in which case measurements at intermediate elevations not more than 12 feet apart are adequate.
 4. At any offsets or abrupt changes in wall dimensions.
- b. At each such elevation a minimum of $D/8$, but not less than four diameters, should be measured at approximately equal intervals around the tank, where D is the tank diameter expressed in feet.
- c. If for any reason it is impractical to take measurements at the positions described in paragraphs (a) and (b), then the diameter should be taken as close to the described position as practicable. The reason for deviations should be recorded in the field notes.
- d. Diameters should be measured, recorded and corrected as specified for underground cylindrical steel tanks in E.2.

E.4 Measurements for Rectangular Steel or Concrete Underground Tanks

- a. Lengths and widths should be measured at the following elevations, as shown in figure E-2:
 1. 1 ft above the tank bottom
 2. 1 ft below the tank roof
 3. At intermediate elevations not more than 6 ft apart, unless it can be shown that the walls are vertical, in which case measurements at intermediate elevations not more than 12 ft apart are adequate.
 4. At any offsets or abrupt changes in wall dimensions.
- b. At each such elevation do the following:
 1. Two width and two length measurements should be made at points 1 foot inside each of the four walls of the tank.
 2. Additional width and length measurements (a minimum of one each) should be made at intermediate points not more than 12 feet apart.

E.4.1 If for any reason it is impractical to take measurements at the positions described in E.3.1, then the length or width should be taken as close to the described position as practicable. The reason for the deviation should be recorded in the field notes.

E.4.2 Length or width should be measured, recorded, and corrected as specified for underground cylindrical steel tanks in E.2.

E.4.3 Vertical dimensions, plate thicknesses, dimensions of tanks of special shape, measurements of deadwood, and any other special measurements, such as those for unstable bottoms, should be made in accordance with procedures described for aboveground upright cylindrical tanks in 2.2A.13 to 2.2A.16 and as outlined in E.1 to E.4, where applicable.

E.5 Calibration Based on Drawings

In the event that the calibration procedures described in E.4 cannot be used, then liquid calibration or other approved optical methods should be considered. For example see Figure F-2 and refer to an insulated tank. Capacity tables may be prepared from computations based on the construction drawings and specifications of the tank builder as the least preferred choice.

APPENDIX F—TANK CALIBRATION METHOD SELECTION^{F-1}

F.1 The type of calibration method selected may often be dictated by a number of factors. These factors are broadly grouped into the following:

- a. Type of tank: Floating or fixed roof.
- b. Operational constraints: entry or no entry.
- c. Insulation or no insulation.
- d. Riveted or welded.
- e. Other parameters such as number/size of wind girders.

F.2 Selection of any specific method for each of the preceding factors is presented in the form of decision charts (Figures F-1, F-2, and F-3). In the development of these guidelines, it is assumed that the insulation requirements pertain only to the fixed roof tanks.



F.3 Also, the term *entry*, as applied to the floating roof tanks, refers to access onto the top of the floating roof with the roof resting on its legs.

F.4 The bottom calibration requirements are not considered separately, because they would belong to the same category where entry is required or permitted.

F.5 For each category, technology selections are presented in a prioritized order. The priority recommended is based upon the most expedient way of calibration for a given set of conditions, ensuring overall accuracy.

F.6 However, the recommended priority is not intended necessarily to optimize the overall cost of calibration. The cost factor associated with any given method is dependent on many factors.

^{F-1}Reproduced in part from *Oil & Gas Journal*, February 5, 1990, Technology Issue. Based an article entitled "Guidelines Help Select Storage Tank Calibration Method" by S. Sivaraman.



API MPMS*2.2A 95 0732290 0543425 931

1-01102—2/95—1M (1E)

American Petroleum Institute
1220 L Street, Northwest
Washington, D.C. 20005



Order No. 852-022A1